

Product change notification (PCN)

Title / short description TRIO-HP/3AC/1KDC/20kW/BI - Firmware update - grid compliance to 200 VAC
Affected article category Power supplies and UPS
Change category Software modification, Marking, Function
Change number CCM260053-00
Reason for PCN/PDN Revision

Purpose/objective of the change
Product optimization

Detailed description of the change
New firmware update to be grid compliance (200 VAC) to Japan network

Identifying characteristics
Identifiable by V/C01 on the type label (see attachment)

Start of Production (SOP)	-	Last Time Delivery (LTD)	-
Effective date (EOP)	2026-10-01	End of Service (EOSR)	-
End of Sales (EOS)	-		

Short-term change (< 6 months) or discontinuation (< 12 months), due to:

- | | | |
|---|--|--|
| ☐ Software / Firmware Bugfix | ☐ Short-term delivery stop by supplier | ☐ Short-term recall by supplier |
| ☐ Force majeure | ☒ Product improvement with customer benefits | |
| ☐ Others | | |

Attachments

- CCM260053_Attachment.pdf
- Material_list.csv
- PCN-CCM260053-00_EN

Material list

Item no.	Item Type	Hardware / Firmware		Item no.	Substitute item Type
		old	new		
1560712	TRIO-HP/3AC/1KDC/20KW/BI	0	1		