## 📑 USER GUIDE TB-9080 💳

## **EM Aware Monitor** Installation, Operation and Maintenance





Figure 1. SCS 770063 EM Aware Monitor

## **Description**

The SCS 770063 EM Aware Monitor monitors three key parameters that keep you aware of critical symptoms of ESD problems: ESD events, change in static voltage field, and ionizer performance\*. The thresholds for these parameters are fully adjustable. The monitor is constructed of an aluminum enclosure, LCD display, control joystick, remote antenna, relay terminal and Ethernet connectivity.

ESD events generate electromagnetic radiation. The stronger the ESD event, the stronger the electromagnetic radiation. The EM Aware Monitor is a miniature radio receiver tuned to detect and measure the unique waveform generated by an ESD event.

The EM Aware Monitor meets the Continuous Monitor requirements of ANSI/ESD S20.20 in accordance with ESD TR1.0-01 and ANSI/ESD STM3.1. It meets the recommendations of ESD Handbook ESD TR20.20 which includes "if the products that are being produced are of such value that knowledge of a continuous, reliable ground is needed, and then continuous monitoring should be considered or even required".

\*Compatible with critical environment ionizers only. The ionizer must have a balance (offset voltage) of ±5V or better.

The EM Aware Monitor and its accessories are available as the following item numbers:

Item	Description
<u>770063</u>	EM Aware Monitor
<u>CTC111-6FT</u>	Antenna, Room Temperature, 6 ft.
<u>CTC118-6FT</u>	Antenna, High Temperature, 6 ft.
770064	Power Adapter, 100-240VAC Input, 7.5VDC 1.5A Output, All Plugs
770055	SMP Software

## SMP

## Static Management Program

The SCS 770063 EM Aware Monitor is compatible with SCS Static Management Program (SMP). SMP continuously monitors your ESD process control system throughout all stages of manufacturing. SMP captures data from SCS workstation, equipment and ESD event continuous monitors and provides a real-time picture of critical manufacturing processes. All activity is stored into a database for on-going quality control purposes. SMP allows you to pinpoint areas of concern and prevent ESD events. Quantifiable data allows you to see trends, become more proactive and prove the efficiency of your ESD process control system.

SMP is sold separately. Click here to learn more.

## Packaging

- 1 EM Aware Monitor
- CTC111-6FT Antenna with 6 ft. Cable 1
- Monitor Ground Cord (Green and Yellow) 1
- 1 Ring Terminal
- Screw, Pan-Head, 6-32 x 1/4" 1
- Star Washer 1
- 1 Power Adapter, 7.5VDC, with interchangeable plugs (North America, UK/Asia, Europe, China)
- Certificate of Calibration 1



Figure 2. EM Aware Monitor features and components

**A. Relay Terminal:** Integrates with electronic tools, lights, buzzers, etc.

**B.** Antenna Input: Connect to the antenna using the included cable.

C. LCD Display: Displays measurements and settings.

**D. Joystick:** Toggles displayed measurements and monitor settings.

**E. Power Jack:** Connect the included 7.5VDC power adapter here.

**F. Ground Terminal:** Common ground point for the monitor.

**G. Ethernet Jack:** Provides network communication between the EM Aware Monitor and <u>Static Management</u> <u>Program (SMP)</u>.

### Installation

#### **Hardware Setup**

- 1. Remove the monitor and antenna from the carton and inspect for damage.
- Determine the installation location of the antenna. For optimal performance, position the antenna as close as practically possible to the anticipated source of ESD activity. Use the mounting tabs on the antenna to properly secure it to the desired location.
- 3. Connect the anntena's cable to the EM Aware Monitor without bending it.
- 4. Determine the mounting location of the monitor. Its display should be visible to the operator. Use the two 4-40 threaded holes at the back of its enclosure if desired.

- Secure one end of the included ground cord to the ground terminal located on the right-side of the monitor. Attach the other end of the cord to a ground point. The face plate screw of a grounded AC wall outlet may provide a convenient connection point.
- 6. Connect an Ethernet cable to the Ethernet jack located on the right-side of the monitor. Verify that the cable is properly connected to a network.
- 7. Connect the power adapter to the power jack located on the right-side of the monitor. Route the wire from the supply to a nearby AC outlet and plug it into the outlet. Make sure the voltage and frequency match those listed on the power supply. The monitor is now powered.



Figure 3. Stand-alone setup for the EM Aware Monitor

#### **Relay Terminal**

The EM Aware Monitor features one optical relay terminal that can be integrated with electronic tools, lights, buzzers, etc. The relay opens when the monitor enters an alarm condition, and it remains closed otherwise. Alarm conditions include ESD events and exceeded static voltage and ionizer balance thresholds.



Figure 4. Relay terminal pin-out

Parameter	Rating
Peak Blocking Voltage	400 V <sub>P</sub>
Load Current	140 mA $_{\rm rms}$ / mA $_{\rm DC}$
On-Resistance (max)	22 ohms

#### **SMP Network Setup**

The following procedure outlines how to connect the EM Aware Monitor to SMP via a local area network (LAN). SMP must be installed to a PC prior to using this procedure.

#### DYNAMIC IP PROCEDURE

- 1. Verify that the Ethernet cable is securely connected to your network and EM Aware Monitor. The LEDs on the Ethernet port will illuminate when a connection to the network is established.
- 2. Open SCS SMP Server Monitor.



3. The SMP Server icon will appear in the Windows taskbar.

1	SM ver SMF	P Ser sion Serve	<b>ver</b> 2.0.6 rMonit	tor		
^	SMP	타	\$₩)	d <sup>a</sup>	3:37 PM 2017-03-08	2

4. Click the SMP Server icon located on the Windows taskbar. The SMP Server menu will appear. Click the Start button to start SMP Server.



5. A message will appear and display "Starting SMP Server..." Click the SMP Server icon located in the Windows taskbar.



6. SMP Server will now indicate Active server status.



7. SMP Server will search and find the EM Aware Monitor on the network. The Device and Active counts will increase to 1.



8. Open SCS SMP #	Admin.	
	S	
	scs	~
	SCS SMP Admin	
	SCS SMP Client	
	SCS SMP Plan Editor	
	SCS SMP Server Monitor	

9. The window for SMP Server Admin will appear. "1 unassigned" is representative of the EM Aware Monitor that was just found by SMP Server. Click the Add New Building button.

SMP Server Admin v.2.0.6		- 🗆 X
SMP Server local 🛛 🎎 🛶 🚩	💊 🛆 📰 🗵 🔅 🕽 🍓	
SMP Server local	Server local	
	buildings: 0 floors: 0 lines: 0 devices: 0 assigned, 1 unassigned	<u>C</u> hange Server Login
	Buildings	Add New Building
		Users e-mail Notifications
		Connections <u>S</u> tatus
	SCS - 926 JR Industrial Drive, Sanford, NC 27332	

10. Enter a building name,	and then click the OK button.
	×
	Add building to server local
	Building name: 926 JR Industrial Drive
	OK
11. The building name will a	appear on the navigation pane in SMP Server Admin.

SMP Server Admin v.2.0.6			– 🗆 X
SMP Server local 🛛 🦀  🚩	🔍 🛆 📰 🗵 🔅 🧊 🐁		
<ul> <li>SMP Server local</li> <li>926 JR Industrial Drive</li> </ul>	Server local		
	buildings: 1 floors: 0 lines: 0 devices: 0 assigned, 1 unassigned Buildings 926 JR Industrial Drive	rename delete	<u>Change Server</u> <u>Login</u> Server Options Add New Building
			e-mail Notifications

12. Click on the building name in the navigation pane, and then click the Add New Floor button.

MP Server local 🛛 🎎  😽 🏲	- 💊 🛕 🛅 🗷 🔅 🧊 🍓	
<ul> <li>SMP Server local</li> <li>926 JR Industrial Drive</li> </ul>	Building 926 JR Industrial Drive	
	floors: 0 lines: 0 devices: 0	<u>R</u> ename Building Delete Building
	Floors	Add New Floor
	SCS - 926 JR Industrial Drive, Sanford, NC 27332 East: (919) 718-0000   West: (909) 627-9634 • Website: <u>StaticControl.co</u>	om

13. Enter a floor name, and	d then click the OK button.	
	Add floor to building 926 JR Industrial Drive Floor name: Laboratory OK Cancel	
14. The floor name will app SMP Server Admin v.2.0.6 SMP Server local & SMP Server local	Dear on the navigation pane in SMP Server Admin.           Image: Server Admin.           Image: Server Admin.           Image: Server Admin.	– – ×
4 926 JR Industrial Drive Laboratory	Building 926 JR Industrial Drive         floors: 1         lines: 0         devices: 0         Floors         Laboratory         rename delete	Rename Building Delete Building Add New Floor

15. Click on the floor name in the navigation pane, and then click the Add New Line button.

▲ SMP Server local	Floor Laboratory	
Laboratory	building <u>926 JR Industrial Drive</u> lines: 0 devices: 0	Rename Floor Delete Floor Edit Plan

16. Enter a line name, and then	click the OK button.	
Ad Line 17. The line name will appear o	Interview     Interview       Interview     Interview       Interview     Interview	
SMP Server Iocal A 926 JR Industrial Drive A Laboratory PCB Assembly	<ul> <li>Image: Constant of the second s</li></ul>	Rename Floor       Delete Floor       Edit Plan         Add New Line

bottom of the window.

<ul> <li>SMP Server local</li> <li>926 JR Industrial Drive</li> <li>Laboratory</li> <li>PCB Assembly</li> </ul>	Line PCB Assembly			
	building <u>926 JR Industrial Drive</u> floor <u>Laboratory</u> devices: <b>0</b>			<u>R</u> ename Line Delete Line
	Attached Devices:			
	Device	Model	Serial	

SMP Server Admin v.2.0.6					>			
SMP Server local 🛛 🎎 👒	🚩 🔍 🛆 🔤 🙁 🔅	J 🔒						
<ul> <li>SMP Server local</li> <li>926 JR Industrial Drive</li> </ul>	Line PCB Assembly	Line PCB Assembly						
Laboratory PCB Assembly	building <u>926 JR Industrial Drive</u> floor <u>Laboratory</u>	building <u>926 JR Industrial Drive</u> floor <u>Laboratory</u>						
	devices: 0	devices: 0						
	Attached Devices:							
	Device	Model	Serial					
	Attachable Devices:	M 11	0.11					
	Name	Model	Serial					
	[E4100400AAAA]	Eivi Aware	L4100400AAAA	attach				

20. The EM Aware Monitor will attach to the selected line.

<ul> <li>✓ 926 JR Industrial Drive</li> <li>✓ Laboratory</li> <li>▶ PCB Assembly</li> </ul>	Line PCB Assembly building 926 JR Industrial Drive floor Laboratory devices: 1					
	Attached Devices:					
	Device	Model	Serial			
	Attachable Devices:					
	Name	Model	Serial			

21. Open SCS SMP Client.		
	S	
	📕 scs	~
	SCS SMP Admin	
	SCS SMP Client	
	SCS SMP Plan Editor	
	SCS SMP Server Monitor	

22. Verify that the EM Aware Monitor was added to the appropriate building, floor and line.

SMP Device Monitoring v.2.0.6						- 🗆 X
Image: Second system       Image: Second system <td< th=""><th>🇊 🐁 🛕</th><th>Find device:</th><th></th><th><u></u></th><th>Ala</th><th>order by: <u>severity tim</u></th></td<>	🇊 🐁 🛕	Find device:		<u></u>	Ala	order by: <u>severity tim</u>
Device	Balan Voltag	:e Static je Voltage	ESD Events	Decay		
[ <u>E4100400AAAA]</u> , EM Aware						
<b>SCS</b> - East: (919) 718-00	• 926 JR Industrial I 000   West: (909) 6	Drive, Sanford, I 27-9634 • Webs	NC 27332 site: <u>StaticC</u>	ontrol.com		

## Operation

**WARNING:** Never apply or discharge voltage directly to the EM Aware Monitor's metal remote antenna as this may cause significant damage to the EM Aware Monitor.

#### **Controlling the EM Aware Monitor**

The EM Aware Monitor is controlled using a 5-position joystick located to the right of its display. The joystick can be toggled left, right, up, and down and pushed inward.

The EM Aware Monitor will default to the ESD Event display upon completion of its boot-up sequence. Toggle the joystick down to advance the display to the next channel, and toggle the joystick up to return to the previous channel. See Figure 5.

Push down and hold the joystick for 3 seconds to enter the displayed settings.



Figure 5. Cycling through the modes on the display

### **ESD Event Channel**



Figure 6. ESD Event channel

**REF:** Indicator appears during ESD event threshold setup.

**ESD Event Counting Mode:** Denotes that ESD event counting is active

ESD Level Bar Graph: Displays the current ESD level.

**ESD Threshold Marker:** Marks the ESD event threshold on the ESD level bar graph.

**MAX:** Indicates the maximum magnitude of ESD event within the last second duration.

**PEAK:** Indicates that the noise filter is enabled. If "PEAK" is not displayed, the noise filter is disabled.

**ESD Counter:** Counts the number of events over the set threshold. The maximum number is 1999 and resets to 0 once this limit is exceeded.

**ESD Event Peaks:** Voltage level that is received by the antenna which is a result of an ESD event near the antenna. It is measured in  $dB\mu V$ .

#### **ESD Event Settings**

- 1. Toggle the joystick until the ESD Event channel is displayed (Figure 6).
- 2. To reset the ESD counter to zero, push down the joystick momentarily.
- 3. To change the ESD threshold, push down and hold the joystick until "ESD" is displayed. The "REF" indicator will appear on the top-left corner of the display to indicate that the ESD threshold value can be modified. Toggle the joystick left to decrease the threshold. Toggle the joystick right to increase the threshold. Hold the joystick in either direction to quickly increment the value.



Figure 7. Modifying the ESD event threshold

4. When the noise filter is enabled, the EM Aware will detect mostly ESD events and ignore other signals such as EMI. If the noise filter is disabled, all signal types will be detected. To disable or enable the noise filter, enter the ESD threshold settings as described in the previous step, and then toggle the joystick up or down. "Cdr OFF" indicates that the filter is disabled, and "Cdr On" indicates that the filter is enabled.



Figure 8. Enabling the noise filter

5. Push down the joystick momentarily to save all settings. "MEM" will appear temporarily in the top left corner while the settings are saved. The monitor will then re-boot after the save is completed.

NOTE: The monitor will revert back to its last saved settings if idled for 10 seconds while in the settings menu. The joystick must be pushed down in order to save all modifications to the settings.

### **Static Voltage Field Channel**



Figure 9. Static Voltage Field channel

**ESD Event Counting Mode:** Indicates that ESD event counting is active.

**Static Voltage Polarity:** Denotes the polarity of the static voltage peaks.

**Static Voltage Level Bar Graph:** Displays the current change in static voltage field magnitude regardless of polarity.

**MAX:** Indicates the maximum magnitude of static voltage within the last second duration.

**PEAK:** Appears when the measured static voltage exceeds the voltage range.

**ESD Counter:** Counts the number events over the set threshold. The maximum number is 1999 and resets to 0 once this limit is exceeded.

**Static Voltage:** The current value of the signal being measured by the antenna expressed in volts.

**Static Voltage Threshold Marker:** Marks the static voltage threshold setting.

# Principle of Operation of Static Voltage Monitor

The Static Voltage channel measures the change of electrostatic field. Any change in electrostatic field induces voltage on the antenna via capacitive coupling. An electrostatic field that is stationary does not induce voltage on the antenna, so the EM Aware will show a decreasing value.

#### **Indication of Static Voltage**

The Static Voltage Level Bar Graph in the bottom left corner of the display indicates absolute magnitude of static voltage regardless of polarity. An audible alarm will sound when voltage of any polarity exceeds the preset alarm level.

#### **Static Voltage Settings**

- 1. Toggle the joystick until the Static Voltage channel is displayed (Figure 9).
- 2. To reset the ESD counter to zero, push down the joystick momentarily.
- 3. To change the voltage range and thresholds, push down and hold the joystick until "REF" is displayed on the top-left corner. "REF" indicates that the settings can be modified.
- 4. Toggle the joystick up or down to scroll through the voltage range options (12.5, 100, 250, 500, 1000 volts). Select the 12.5 volt range to enable the ionization balance function if desired.
- Toggle the joystick left to decrease the threshold. Toggle the joystick right to increase the threshold. Hold the joystick in either direction to quickly increment the value.
- 6. Push down the joystick momentarily to save all settings. "MEM" will appear temporarily in the top left corner while the settings are saved. The monitor will then re-boot after the save is completed.

NOTE: The monitor will revert back to its last saved settings if idled for 10 seconds while in the settings menu. The joystick must be pushed down in order to save all modifications to the settings.

#### **Ionization Balance and Decay Channel**



Figure 10. Balance and Decay Mode channel

**Ionization Balance Polarity:** Indicates the polarity of the ionizer's balance (offset voltage).

**Decay Measurement in Progress:** Appears when the decay time is being measured.

**Ionization Balance Level Bar Graph:** Indicates the balance (offset voltage) levels.

**Ionization Balance:** Displays the ionizer's balance (offset voltage).

**Decay Time:** Displays the amount of seconds to decay a static charge. "1--.--" will display if the decay time exceeds 16 seconds.

**Ionization Balance Threshold Marker:** Marks the balance (offset voltage) threshold setting.

NOTE: The EM Aware Monitor is compatible with steady-state DC critical environment ionizers only. The ionizer must have a balance (offset voltage) of ±5V or better.

#### **Ionization Balance and Decay Settings**

NOTE: These settings cannot be changed unless the static voltage range is set to 12.5 volts. See "Static Voltage Settings" on page 4.

- 1. Toggle the joystick until the lonization Balance and Decay channel are displayed (Figure 10).
- 2. Push down the joystick momentarily to manually measure the ionizer's balance (offset voltage) and decay time. The \*- symbols will appear while the measurements are being taken. The balance (upper row) and decay time (lower row) will update at the end of the tests. Balance and decay time are automatically measured every three minutes. Static voltage monitoring becomes idle when balance and decay tests are performed. ESD event monitoring operates normally.
- 3. To change the voltage range and thresholds, push down and hold the joystick until "REF" is displayed on the top-left corner. "REF" indicates that the settings can be modified. The value in the top row indicates the current balance threshold, and the value in the bottom row indicates the decay time threshold.
- 4. Toggle the joystick down to decrease the decay time threshold. Toggle the joystick up to increase the decay time threshold. Hold the joystick in either direction to quickly increment the value.



Figure 11. Decay time threshold settings

5. Toggle the joystick left to decrease the balance threshold. Toggle the joystick right to increase the balance threshold. Hold the joystick in either direction to quickly increment the value.



Figure 12. Ionization balance screen

 Push down the joystick momentarily to save all settings. "MEM" will appear temporarily in the top left corner while the settings are saved. The monitor will then re-boot after the save is completed.

NOTE: The monitor will revert back to its last saved settings if idled for 10 seconds while in the settings menu. The joystick must be pushed down in order to save all modifications to the settings.

#### **Audible Alarm Settings**

1. Toggle the joystick until the Sound channel is displayed.



Figure 13. Sound On/Off screen

2. To change the audible alarm setting, push down and hold the joystick until the setting below "Snd" blinks.



Figure 14. Sound On/Off change screen

- 3. Toggle the joystick left or right to disable or enable the audible alarm.
- 4. Push down the joystick momentarily to save all settings. "MEM" will appear temporarily in the top left corner while the settings are saved. The monitor will then re-boot after the save is completed.

#### **Smart Coefficient (SCF)**

The Smart Coefficient (SCF) feature works in conjunction with the static voltage field channel. This feature is useful when an approximate voltage is desired, especially when the distance is not exact. For example, a known 1000V static voltage source should show approximately 1000V on the EM Aware Monitor when its antenna is 5 inches away from the static voltage source. This 1000V approximation will change as the antenna is located further away from the static voltage source. It may show a value close to 600V instead.

The Smart Coefficient function allows a correction factor to compensate for the variable distance. To bring the approximated voltage value back to 1000V, the SCF value will have to be set to 1.66. Alternatively, if the antenna is moved closer, the monitor may show 1400V. In this case, an SCF value of 0.71 will bring the reading back to 1000V.

NOTE: All numbers referenced in the previous paragraph are for illustration purposes only. They should not be referenced for accuracy.

The Smart Coefficient has a default setting of 1.000, and it can be adjusted from 0.001 to 1.999. When adjusting the Smart Coefficient, it is important to have a known static voltage source as a reference for setting the SCF value. This voltage source may be a Pulse Generator, a Charged Plate Monitor (1 KV typically), or a Function Generator.

#### **Smart Coefficient (SCF) Settings**

1. Toggle the joystick until the Smart Coefficient channel is displayed.



Figure 15. Smart Coefficient channel

 To change the Smart Coefficient value, push down and hold the joystick until the value blinks and "REF" is displayed on the top-left corner. "REF" indicates that the settings can be modified.



Figure 16. Setting the Smart Coefficient value

- 3. Toggle the joystick left to decrease the value. Toggle the joystick right to increase the value. Hold the joystick in either direction to quickly increment the value.
- 4. Push down the joystick momentarily to save all settings. "MEM" will appear temporarily in the top left corner while the settings are saved. The monitor will then re-boot after the save is completed.

NOTE: The monitor will automatically save the value on the display if idled for 10 seconds while in the settings menu.

#### **EM Aware Calculator Software**

Use the EM Aware Calculator to estimate ESD event voltages. Simply enter the  $dB\mu V$  measurement from the EM Aware Monitor and the distance from the event source to the remote antenna. The EM Aware Calculator will provide an approximate voltage for the ESD event based on CDM, HBM and MM models.

- Use the link below to download the EM Aware Calculator Software. <u>http://staticcontrol.descoindustries.com/Downloads/</u> <u>EMAwareCalculator.zip</u>
- 2. Extract the contents of the zip folder, and run "setup.exe". Follow the on-screen prompts to install the software.
- Run the EM Aware Calculator to estimate ESD event voltages based off dBµV measurements from the EM Aware Monitor and distance settings.

ses EM Aware TNG Calculator	/3.0.3		- 🗆 X		
	Model Machine Model Human Body Model Charge Device Model		Antenna O Local Remote		
Parameter EM Aware linear volta	ge	Estimated tr	ue ESD voltage		
0.001V		4V			
Distance		<b>0.5</b> (inch)	1.27 (cm)		
0.5	15	<b>60.0</b> (dBµV	) LCD/SMP reading		
EM Aware LCD or SMP dBµV	/Value :	1.00 (Volt)	DATAQ reading		
60.0			134.0		
	Help	© 2015 Des	co Industries		

Figure 17. EM Aware Calculator Software

### Maintenance

#### Cleaning

Disconnect the power adapter from the device. Clean the EM Aware Monitor and its antenna using a dry brush or vacuum cleaner. Clean its contacts using a contact cleaner or brush, and tighten all connections. Do not reconnect the power adapter until cleaning is finished.

#### **Repairs and Servicing**

There are no user-serviceable parts. Do not attempt to repair the EM Aware Monitor yourself. Contact an SCS sales representative or authorized distributor to request inspection and repair.

## Calibration

Contact an SCS sales representative or authorized distributor to request for product calibration if necessary.

#### **Specifications** Power Power Adapter Output: 7.5VDC @ 1.5A 100-240VAC **Output Plug Polarization: Center** 50-60 Hz Positive Output Plug: 5.5 mm O.D. x 2.1 mm I.D. x 9.5 mm L **ESD Event Monitor** Measurement Magnitude ESD Event ESD Event Default setting: 80 dBµV Threshold Raw Input Signal 60 dBµV (~1mV) to 134 dBµV (~5.0V) ESD Filtering Function **Static Voltage Monitor** Measurement Static Voltage - Change of electrostatic field Static Voltage 12.5V, 100V, 250V, 500V, 1000V, smart coefficient adjust Setting Range Output Ethernet **Ionizer Voltage and Decay Monitor** Compatible Ionizer Steady-State DC Max. Decay Time 16 seconds\*\* max, typical Reading Max. Decay Test (+) and (-) 5 Volt Voltage Connectivity SMA Connector for Remote Input antenna Outputs RJ45 connector for Ethernet output; 2-position terminal block for relay output General Alarm Buzzer Display LCD Dimensions 3.17" W x 2.25" H x 1.26" D (antenna not (81 mm W x 57 mm H x 32 mm D) included) Weight 183g \*\*The readings of ionization voltage and decay under

\*\*The readings of ionization voltage and decay under identical conditions may not always correlate with a charged plate monitor. The EM Aware Monitor is not intended to replace regular testing of ionizers by a charged plate monitor.

### **Safety Information**

Please read, understand, and follow all safety information contained in these instructions prior to the use of this device. Retain these instructions for future reference.

#### Intended Use

The SCS EM Aware Monitor monitors up to three key parameters that keep you aware of critical symptoms of ESD problems: ESD events, change in static voltage field, and ionizer performance. The thresholds for these parameters are fully adjustable. The monitor is constructed of an aluminum enclosure, LCD display, control joystick, remote antenna, power adapter and data output terminal.

The systems must be installed as specified in this user guide in an indoor commercial/industrial environment, and have not been evaluated for other uses or locations. If the equipment is used in a manner not specified by the manufacturer, the protection provided by the equipment may be impaired.

#### Warning

To reduce the risks associated with hazardous voltage and fire:

- Do not use the power supply if damaged
- Replace power supply if damaged using only SCS supplied parts.
- Do not modify or attempt to service the power supply. Return to SCS for service.
- Do not use the EM Aware Monitor or its power supply outdoors or in wet/humid environments.
- Do not use the EM Aware Monitor or its power supply outside of the operating conditions listed in this User Guide.
- Use only a dry cloth when cleaning.

To reduce the risks associated with hazardous voltage:

- Use only the power supply provided by SCS and specified for the country of use.
- Do not simultaneously power the EM Aware Monitor with the power supply and the RJ45 data cable.
- Do not position the monitor accessories or other equipment where unplugging the power supply is difficult.
- Always locate the power source (socket or outlet) near the equipment. The power supply plug serves as the disconnect device.

#### Caution

To reduce the risks associated with environmental contamination:

• Dispose of monitor and power supply in accordance with all applicable local and government regulations.

#### Notice

To reduce the risk of damage to components or assemblies being handled:

- Monitor must be checked periodically to verify each test mode is functioning correctly.
- Ensure proper operation of the monitor by performing operational verification test as required.
- Always properly ground your tools and dissipative surfaces to before connecting them to the EM Aware Monitor.

#### FCC

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in a residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

#### Industry Canada ICES-003 Compliance: CAN ICES-3 (A)/NMB-3(A)

## **Environmental Conditions**

This equipment has been tested and found to be safe to operate within these environmental conditions.

This is not a warranty of equipment performance within these conditions.

- Indoor use only
- Ingress Protection: IPX0
- Altitude: Up to 2,000 m
- Mains supply voltage fluctuations up to ± 10% of the nominal voltage.
- Transient over-voltages up to the levels of overvoltage category II.
- Temporary over-voltages occurring on mains supply.
- Pollution degree 2.
- Temperature: Maximum 110°F / 43°C, Minimum 50°F / 10°C
- Humidity: Maximum relative humidity 80% for temperatures up to 31°C decreasing linearly to 50% relative humidity at 40°C.

## **Regulatory Information**

#### China RoHS

## Electronic Industry Standard of the People's Republic of China, SJ T11363-2006, Requirements for Concentration Limits for Certain Hazardous Substances in Electronic Information Products

This symbol, per Marking for the Control of Pollution Caused by Electronic Information Products, SJ/T11364-2006, means that the product or part does contain a substance, as detailed in the chart below, in excess of the following maximum concentration values in any homogeneous material: (a) 0.1% (by weight) for lead, mercury, hexavalent chromium, polybrominated biphenyls or polybrominated diphenyl ethers; or (b) 0.01% (by weight) for cadmium. Unless otherwise stated by S

20

material: (a) 0.1% (by weight) for lead, mercury, hexavalent chromium, polybrominated biphenyls or polybrominated diphenyl ethers; or (b) 0.01% (by weight) for cadmium. Unless otherwise stated by SCS in writing, this information represents our best knowledge and belief based upon information provided by third party suppliers to SCS.

Dart ar Component Name	Hazardous Substances or Elements							
Fait of Component Name	(Pb)	(Hg)	(Cd)	(CrVI)	(PBB)	(PBDE)		
Solder in instrument	Х	0	0	0	0	0		

O: Indicates that this hazardous substance contained in all of the homogeneous materials for this part is below the limit requirement in the SJ/T11363-2006.

X: Indicates that this hazardous substance contained in at least one of the homogeneous materials used for this part is above the limit requirement in the SJ/T11363-2006.

# Limited Warranty, Warranty Exclusions, Limit of Liability and RMA Request Instructions

See the SCS Warranty -StaticControl.com/Limited-Warranty.aspx

## **Mouser Electronics**

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Desco: CTC111-6FT

SCS: 770063