SIEMENS

Data sheet

3RT1926-2ED31



solid-state time-delayed front-side auxiliary switch Time range 5...100 s, 200 \dots 240 V AC, 1 NO contact, 1 NC contact ON delay, for 3RT1


3871/06-2 AZ	
product brand name	SIRIUS
product designation	auxiliary switch
design of the product	slow-operating
product type designation	3RT19
General technical data	
size of contactor can be combined company-specific	S6 S12
product component semi-conductor output	No
product extension required remote control	No
product extension optional remote control	No
insulation voltage for overvoltage category III according to IEC 60664 with degree of pollution 3 rated value	300 V
degree of pollution	3
surge voltage resistance rated value	4 000 V
shock resistance according to IEC 60068-2-27	11g / 15 ms
vibration resistance according to IEC 60068-2-6	10 55 Hz: 0.35 mm
mechanical service life (operating cycles) typical	10 000 000
electrical endurance (operating cycles) at AC-15 at 230 V typical	100 000
adjustable time	5 100 s
relative setting accuracy relating to full-scale value	15 %
recovery time	150 ms
reference code according to IEC 81346-2	К
active principle	electronic
relative repeat accuracy	1 %
Substance Prohibitance (Date)	07/01/2006
SVHC substance name	Lead - 7439-92-1 Lead monoxide (lead oxide) - 1317-36-8
Weight	0.093 kg
Product Function	
product function star-delta circuit	No
Control circuit/ Control	
type of voltage of the control supply voltage	AC
control supply voltage 1 at AC	
• at 50 Hz	200 240 V
• at 60 Hz	200 240 V
control supply voltage frequency 1	50 60 Hz
operating range factor control supply voltage rated value at AC at 50 Hz	
• initial value	0.85
• full-scale value	1.1
operating range factor control supply voltage rated value at AC at 60 Hz	


• initial value	0.85
 initial value full-scale value 	1.1
Switching Function	
switching function	
ON-delay	Yes
-	No
 ON-delay/instantaneous contact passing make contact 	No
passing make contact/instantaneous contact	No
OFF delay switching function	No
-	No
 flashing symmetrically with interval start/instantaneous flashing symmetrically with interval start 	No
flashing symmetrically with nite valistant flashing symmetrically with pulse start/instantaneous	No
flashing symmetrically with pulse start	No
 flashing asymmetrically with interval start flashing asymmetrically with pulse start 	No
switching function	INU
	No
constant clock cycle with pulse start constant clock cycle with interval start	No
constant clock cycle with interval start	
switching function	No
variably clocked with pulse start	No
variably clocked with interval start	No
switching function	No
star-delta circuit with delay time star-delta circuit	No
star-delta circuit	No
switching function with control signal	No
additive ON-delay	No
passing break contact	No
passing break contact/instantaneous	No
OFF delay	No
OFF delay/instantaneous	No
pulse delayed	No
pulse delayed/instantaneous	No
pulse-shaping	No
 pulse-shaping/instantaneous additive ON-delay/instantaneous 	No
additive ON-delay/Instantaneous ON-delay/OFF-delay	No
	No
ON-delay/OFF-delay/instantaneous passing make contact	No
passing make contact passing make contact/instantaneous contact	No
passing make contact/instantaneous contact	No
switching function of interval relay with control signal	No
 retrotriggerable with deactivated control signal/instantaneous contact 	No
 retrotriggerable with switched-on control signal 	No
 retrotriggerable with switched-on control 	No
signal/instantaneous contact	
 retriggerable with deactivated control signal 	No
design of the control terminal non-floating	No
Short-circuit protection	
design of the fuse link for short-circuit protection of the auxiliary	fuse gL/gG: 4 A
switch required	
Auxiliary circuit	
number of NC contacts	
delayed switching	1
instantaneous contact	0
number of NO contacts	
delayed switching	1
instantaneous contact	0
number of CO contacts	
delayed switching	0
 instantaneous contact 	0


operational current of auxiliary contacts at AC-15	
• maximum	3 A
operational current of auxiliary contacts as NC contact at AC-15	
• at 24 V	3 A
• at 250 V	3 A
operational current of auxiliary contacts as NO contact at AC-15	
• at 24 V	3 A
• at 250 V	3 A
operational current of auxiliary contacts at DC-13	
• at 24 V	1A
• at 125 V	0.2 A
• at 250 V	0.1 A
Inputs/ Outputs	
product function	
at the relay outputs switchover delayed/without delay	No
ar the relay outputs switchover delayed/without delay ono-volatile	No
Electromagnetic compatibility	NU
	EN 61000 6 2
EMC immunity according to IEC 61812-1	EN 61000-6-2
conducted interference	0 lat not walk composition (4 lat - start - to start
due to burst according to IEC 61000-4-4	2 kV network connection / 1 kV control connection
due to conductor-earth surge according to IEC 61000-4-5	2 kV
 due to conductor-conductor surge according to IEC 61000-4-5 	1 kV
field-based interference according to IEC 61000-4-3	10 V/m
electrostatic discharge according to IEC 61000-4-2	4 kV contact discharge / 8 kV air discharge
Safety related data	
category according to EN 954-1	none
Electrical Safety	none
protection class IP on the front according to IEC 60529	IP20
touch protection on the front according to IEC 60529	finger-safe, for vertical contact from the front
type of insulation	Basic insulation
Connections/ Terminals	
product component removable terminal for auxiliary and	No
control circuit	
type of electrical connection for auxiliary and control circuit	screw-type terminals
type of connectable conductor cross-sections	
• solid	1x (0.5 4.0 mm²), 2x (0.5 2.5 mm²)
 finely stranded with core end processing 	1x (0.5 2.5 mm²), 2x (0.5 1.5 mm²)
 for AWG cables solid 	2x (20 14)
 for AWG cables stranded 	2x (20 14)
connectable conductor cross-section	
• solid	0.5 4 m²
 finely stranded with core end processing 	0.5 2.5 m²
AWG number as coded connectable conductor cross section	
• solid	18 14
• stranded	18 14
Installation/ mounting/ dimensions	
mounting position	any
fastening method	clip-on
height	46 mm
width	33 mm
depth	73 mm
dopui	
required spacing	
•	
required spacing	0 m
• with side-by-side mounting	0 m 0 m
• with side-by-side mounting — forwards	
 required spacing with side-by-side mounting forwards backwards 	0 m
required spacing with side-by-side mounting forwards backwards upwards 	0 m 0 m

 for grounded patient 	arts				
0 1					
— forwards		0 m			
- backward	S	0 m			
— upwards		0 m			
— at the side	— at the side				
— downward	s	0 m			
 for live parts 					
— forwards		0 m			
- backward	S	0 m			
— upwards		0 m			
— downward	ds	0 m			
— at the side		0 m			
nbient conditions					
nstallation altitude at	height above sea level ma	ximum 2 000) m		
ambient temperature	9				
during operation		-25	. +60 °C		
 during storage 		-40	. +85 °C		
 during transpor 	t	-40	. +85 °C		
elative humidity durin	ng operation	15	95 %		
provals Certificates	3				
General Product Ap	proval				
	CE EG-Konf.	UK CA	<u>Confirmation</u>	(h)	EHC
	EG-Konf.	CA			EHC
CCC EMV		CA	Marine / Shipping	Ű	EHC
	EG-Konf.	UK CA Special Test Certific- ate			EHC
	EG-Konf. Test Certificates Type Test Certific-	Special Test Certific-	Marine / Shipping		EHC
	EG-Konf. Test Certificates Type Test Certific-	Special Test Certific- ate	Marine / Shipping		EHC
EMV EMV Confirmation	EG-Konf.	Special Test Certific- ate Railway Special Test Certific-	Marine / Shipping		EHC
EMV EMV Confirmation	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate	Marine / Shipping		EHC
EMV EMV Confirmation	EG-Konf. Test Certificates Type Test Certific- ates/Test Report Miscellaneous Miscellaneous ackaging y.siemens.com/cs/ww/en/A wnloadcenter (Catalogs,	Special Test Certific- ate Railway Special Test Certific- ate	Marine / Shipping		EHC
EMV EMV Confirmation Confirmation Confirmation Information on the p Information on the p Information on the p Information on the p Information and Do Information and Do Information and Do	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate	Marine / Shipping		EHC
EMV EMV Confirmation other Confirmation formation on the p https://support.industr nformation- and Do https://www.siemens.o ndustry Mall (Online https://mall.industry.si	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate	Marine / Shipping		EHC
EMV EMV EMV other Confirmation Confirmation Information on the p nttps://support.industr nformation- and Do ittps://www.siemens.or ndustry Mall (Online ittps://mall.industry.si Cax online generato	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate ////////////////////////////////////	Marine / Shipping		EHC
EMV EMV Confirmation other Confirmation formation on the p https://support.industry nformation- and Do nttps://support.industry ndustry Mall (Online ttps://mall.industry.si Cax online generato nttps://support.automal Service&Support (M	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate	Marine / Shipping		EHC
EMV EMV Confirmation other Confirmation Information on the p Inters://support.industry information - and Doo https://support.industry information - and Doo https://support.industry industry Mall (Online inters://support.automat Service&Support (M ittps://support.industry mage database (pro	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate iew/109813875 Brochures,) talog/product?mlfb=3RT19 Xorder/default.aspx?lang=racteristics, FAQs,) bs/3RT1926-2ED31 ion drawings, 3D models	Marine / Shipping Marine / Shipping ABS Environment Environmental Con- firmations 226-2ED31 en&mlfb=3RT1926-2ED31 c, device circuit diagrams, I		EHC
EMV EMV Confirmation other Confirmation Information on the p Inters://support.industry information - and Doo https://support.industry information - and Doo https://support.industry industry Mall (Online inters://support.automat Service&Support (M ittps://support.industry mage database (pro	EG-Konf.	Special Test Certific- ate Railway Special Test Certific- ate iew/109813875 Brochures,) talog/product?mlfb=3RT19 Xorder/default.aspx?lang=racteristics, FAQs,) bs/3RT1926-2ED31 ion drawings, 3D models	Marine / Shipping Marine / Shipping ABS Environment Environmental Con- firmations 226-2ED31 en&mlfb=3RT1926-2ED31 c, device circuit diagrams, I		EHC

https://support.industry.siemens.com/cs/ww/en/ps/3RT1926-2ED31/manual







last modified:

6/3/2024 🖸

Subject to change without notice © Copyright Siemens

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens:

3RT19262ED31