## SIEMENS

## Data sheet

## 3RT2038-1AN24



power contactor, AC-3e/AC-3, 80 A, 37 kW / 400 V, 3-pole, 220 V AC, 50/60 Hz, auxiliary contacts: 2 NO + 2 NC, screw terminal, size: S2, removable auxiliary switch

product brand name	SIRIUS
product designation	Power contactor
product type designation	3RT2
General technical data	
size of contactor	S2
product extension	
<ul> <li>function module for communication</li> </ul>	No
<ul> <li>auxiliary switch</li> </ul>	No
power loss [W] for rated value of the current	
<ul> <li>at AC in hot operating state</li> </ul>	17.1 W
<ul> <li>at AC in hot operating state per pole</li> </ul>	5.7 W
<ul> <li>without load current share typical</li> </ul>	6.5 W
insulation voltage	
<ul> <li>of main circuit with degree of pollution 3 rated value</li> </ul>	690 V
<ul> <li>of auxiliary circuit with degree of pollution 3 rated value</li> </ul>	690 V
surge voltage resistance	
<ul> <li>of main circuit rated value</li> </ul>	6 kV
<ul> <li>of auxiliary circuit rated value</li> </ul>	6 kV
maximum permissible voltage for protective separation between coil and main contacts according to EN 60947-1	400 V
shock resistance at rectangular impulse	
• at AC	9.8g / 5 ms, 6.5g / 10 ms
shock resistance with sine pulse	
• at AC	15.3g / 5 ms, 10.1g / 10 ms
mechanical service life (operating cycles)	
<ul> <li>of contactor typical</li> </ul>	10 000 000
<ul> <li>of the contactor with added electronically optimized auxiliary switch block typical</li> </ul>	5 000 000
<ul> <li>of the contactor with added auxiliary switch block typical</li> </ul>	10 000 000
reference code according to IEC 81346-2	Q
Substance Prohibitance (Date)	10/01/2014
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	
<ul> <li>during operation</li> </ul>	-25 +60 °C
during storage	-55 +80 °C
relative humidity minimum	10 %
relative humidity at 55 °C according to IEC 60068-2-30 maximum	95 %
Main circuit	
number of poles for main current circuit	3

number of NO contacts for main contacts	3
operating voltage	
at AC-3 rated value maximum	690 V
<ul> <li>at AC-3e rated value maximum</li> </ul>	690 V
operational current	
• at AC-1 at 400 V at ambient temperature 40 °C rated	90 A
value	
• at AC-1	
— up to 690 V at ambient temperature 40 °C rated value	90 A
— up to 690 V at ambient temperature 60 °C rated	80 A
value	
• at AC-3	
— at 400 V rated value	80 A
— at 500 V rated value	80 A
— at 690 V rated value	58 A
• at AC-3e	
— at 400 V rated value	80 A
— at 500 V rated value	80 A
— at 690 V rated value	58 A
at AC-4 at 400 V rated value	55 A
at AC-5a up to 690 V rated value	79.2 A
<ul> <li>at AC-5b up to 400 V rated value</li> <li>at AC-6a</li> </ul>	66.4 A
	70 A
— up to 230 V for current peak value n=20 rated value	
<ul> <li>— up to 400 V for current peak value n=20 rated value</li> <li>— up to 500 V for current peak value n=20 rated value</li> </ul>	70 A 70 A
— up to 500 V for current peak value n=20 rated value	58 A
• at AC-6a	50 A
<ul> <li>up to 230 V for current peak value n=30 rated value</li> </ul>	46.7 A
— up to 200 V for current peak value n=30 rated value	46.7 A
— up to 500 V for current peak value n=30 rated value	46.7 A
— up to 690 V for current peak value n=30 rated value	46.7 A
minimum cross-section in main circuit at maximum AC-1 rated	35 mm <sup>2</sup>
value	
operational current for approx. 200000 operating cycles at AC-4	
at 400 V rated value	30 A
at 690 V rated value	24 A
operational current	
• at 1 current path at DC-1	
— at 24 V rated value	55 A
— at 60 V rated value	23 A
— at 110 V rated value	4.5 A
— at 220 V rated value	1 A
— at 440 V rated value	0.4 A
— at 600 V rated value	0.25 A
• with 2 current paths in series at DC-1	
— at 24 V rated value	55 A
— at 60 V rated value	45 A
— at 110 V rated value	45 A
— at 220 V rated value	5 A
— at 440 V rated value	1 A
— at 600 V rated value	0.8 A
<ul> <li>with 3 current paths in series at DC-1</li> </ul>	
— at 24 V rated value	55 A
— at 60 V rated value	55 A
— at 110 V rated value	55 A
— at 220 V rated value	45 A
— at 440 V rated value	2.9 A
— at 600 V rated value	1.4 A
<ul> <li>at 1 current path at DC-3 at DC-5</li> </ul>	


— at 24 V rated value	35 A
— at 60 V rated value	6 A
— at 220 V rated value	1 A
— at 440 V rated value	0.1 A
— at 600 V rated value	0.06 A
<ul> <li>with 2 current paths in series at DC-3 at DC-5</li> </ul>	
— at 24 V rated value	55 A
— at 60 V rated value	45 A
— at 110 V rated value	25 A
— at 220 V rated value	5 A
— at 440 V rated value	0.27 A
— at 600 V rated value	0.16 A
<ul> <li>with 3 current paths in series at DC-3 at DC-5</li> </ul>	
— at 24 V rated value	55 A
— at 60 V rated value	55 A
— at 110 V rated value	55 A
— at 220 V rated value	25 A
— at 440 V rated value	0.6 A
— at 600 V rated value	0.35 A
operating power	
at AC-2 at 400 V rated value	37 kW
• at AC-3	
- at 230 V rated value	22 kW
— at 200 V rated value	37 kW
	37 KW
- at 500 V rated value	
— at 690 V rated value	45 kW
• at AC-3e	
- at 230 V rated value	22 kW
— at 400 V rated value	37 kW
— at 500 V rated value	37 kW
— at 690 V rated value	45 kW
operating power for approx. 200000 operating cycles at AC- 4	
<ul> <li>at 400 V rated value</li> </ul>	15.8 kW
at 690 V rated value	21.8 kW
operating apparent power at AC-6a	
up to 230 V for current peak value n=20 rated value	27.8 kVA
• up to 400 V for current peak value n=20 rated value	48.4 kVA
• up to 500 V for current peak value n=20 rated value	60.6 kVA
	69.3 kVA
up to 690 V for current peak value n=20 rated value	00.0 KVA
operating apparent power at AC-6a	18.6 kV/A
up to 230 V for current peak value n=30 rated value	18.6 kVA
• up to 400 V for current peak value n=30 rated value	32.3 kVA
up to 500 V for current peak value n=30 rated value	40.4 kVA
up to 690 V for current peak value n=30 rated value	55.8 kVA
short-time withstand current in cold operating state up to 40 °C	
<ul> <li>limited to 1 s switching at zero current maximum</li> </ul>	1 298 A; Use minimum cross-section acc. to AC-1 rated value
<ul> <li>limited to 5 s switching at zero current maximum</li> </ul>	898 A; Use minimum cross-section acc. to AC-1 rated value
<ul> <li>limited to 10 s switching at zero current maximum</li> </ul>	640 A; Use minimum cross-section acc. to AC-1 rated value
<ul> <li>limited to 30 s switching at zero current maximum</li> </ul>	414 A; Use minimum cross-section acc. to AC-1 rated value
<ul> <li>limited to 60 s switching at zero current maximum</li> </ul>	333 A; Use minimum cross-section acc. to AC-1 rated value
no-load switching frequency	
• at AC	5 000 1/h
operating frequency	
at AC-1 maximum	700 1/h
	350 1/h
• at AC-2 maximum	
• at AC-3 maximum	500 1/h
at AC-3e maximum	500 1/h
at AC-4 maximum	150 1/h
Control circuit/ Control	


type of voltage of the control supply voltage	AC
control supply voltage at AC	
• at 50 Hz rated value	220 V
• at 60 Hz rated value	220 V
operating range factor control supply voltage rated value of magnet coil at AC	
• at 50 Hz	0.8 1.1
• at 60 Hz	0.85 1.1
apparent pick-up power of magnet coil at AC	
• at 50 Hz	210 VA
• at 60 Hz	188 VA
inductive power factor with closing power of the coil	
• at 50 Hz	0.69
● at 60 Hz	0.65
apparent holding power of magnet coil at AC	
• at 50 Hz	17.2 VA
● at 60 Hz	16.5 VA
inductive power factor with the holding power of the coil	
• at 50 Hz	0.36
● at 60 Hz	0.39
closing delay	
• at AC	10 80 ms
opening delay	
• at AC	10 18 ms
arcing time	10 20 ms
control version of the switch operating mechanism	Standard A1 - A2
Auxiliary circuit	
number of NC contacts for auxiliary contacts instantaneous contact	2
number of NO contacts for auxiliary contacts instantaneous contact	2
operational current at AC-12 maximum	10 A
operational current at AC-15	
• at 230 V rated value	6 A
• at 400 V rated value	3 A
• at 500 V rated value	2 A
• at 690 V rated value	1 A
operational current at DC-12	
• at 24 V rated value	10 A
• at 48 V rated value	6 A
● at 60 V rated value	6 A
• at 110 V rated value	3 A
• at 125 V rated value	2 A
• at 220 V rated value	1 A
• at 600 V rated value	0.15 A
operational current at DC-13	
• at 24 V rated value	6 A
• at 48 V rated value	2 A
• at 60 V rated value	2 A
• at 110 V rated value	1 A
• at 125 V rated value	0.9 A
• at 220 V rated value	0.3 A
• at 600 V rated value	0.1 A
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
<ul> <li>full-load current (FLA) for 3-phase AC motor</li> <li>at 480 V rated value</li> </ul>	65 A
	65 A 62 A
• at 480 V rated value	
<ul><li>at 480 V rated value</li><li>at 600 V rated value</li></ul>	
at 480 V rated value     at 600 V rated value yielded mechanical performance [hp]	

— at 230 V rated value	15 hp
for 3-phase AC motor	
— at 200/208 V rated value	20 hp
— at 220/230 V rated value	25 hp
— at 460/480 V rated value	50 hp
— at 575/600 V rated value	60 hp
contact rating of auxiliary contacts according to UL	A600 / Q600
Short-circuit protection	
design of the fuse link	
<ul> <li>for short-circuit protection of the main circuit</li> </ul>	
<ul> <li>— with type of coordination 1 required</li> </ul>	gG: 250 A (690 V, 100 kA), aM: 160 A (690 V, 100 kA), BS88: 200 A (415 V, 80 kA)
<ul> <li>— with type of assignment 2 required</li> </ul>	gG: 160A (690V,100kA), aM: 80A (690V,100kA), BS88: 125A (415V,80kA)
<ul> <li>for short-circuit protection of the auxiliary switch required</li> </ul>	gG: 10 A (500 V, 1 kA)
Installation/ mounting/ dimensions	
mounting position	+/-180° rotation possible on vertical mounting surface; can be tilted forward and backward by +/- 22.5° on vertical mounting surface
fastening method	screw and snap-on mounting onto 35 mm DIN rail according to DIN EN 60715
side-by-side mounting	Yes
height	114 mm
width	55 mm
depth	174 mm
required spacing	
with side-by-side mounting	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	0 mm
for grounded parts	
— forwards	10 mm
— upwards	10 mm
— at the side	6 mm
— downwards	10 mm
for live parts	
— forwards	10 mm
— upwards	10 mm
— downwards	10 mm
— at the side	6 mm
Connections/ Terminals	Unini
type of electrical connection	acrow two terminals
for main current circuit     for auxiliany and control circuit	screw-type terminals
for auxiliary and control circuit     at contactor for auxiliary contacto	screw-type terminals
at contactor for auxiliary contacts	Screw-type terminals
of magnet coil      type of connectable conductor cross sections for main contacts	Screw-type terminals
type of connectable conductor cross-sections for main contacts	$2x/(1 - 25 \text{ mm}^2) + 1x/(1 - 50 \text{ mm}^2)$
<ul> <li>solid or stranded</li> <li>finally stranded with core and processing</li> </ul>	$2x (1 35 \text{ mm}^2), 1x (1 50 \text{ mm}^2)$
finely stranded with core end processing	2x (1 25 mm²), 1x (1 35 mm²)
connectable conductor cross-section for main contacts	1 25 mm <sup>2</sup>
finely stranded with core end processing	1 35 mm <sup>2</sup>
connectable conductor cross-section for auxiliary contacts	0.5 0.5 mm²
solid or stranded	0.5 2.5 mm <sup>2</sup>
finely stranded with core end processing	0.5 2.5 mm²
type of connectable conductor cross-sections	
for auxiliary contacts	
— solid or stranded	2x (0.5 1.5 mm <sup>2</sup> ), 2x (0.75 2.5 mm <sup>2</sup> )
— finely stranded with core end processing	2x (0.5 1.5 mm <sup>2</sup> ), 2x (0.75 2.5 mm <sup>2</sup> )
for AWG cables for auxiliary contacts	2x (20 16), 2x (18 14)
AWG number as coded connectable conductor cross section	
for main contacts	18 1
<ul> <li>for auxiliary contacts</li> </ul>	20 14

statu raistad data					
afety related data		_			
product function					
<ul> <li>mirror contact a</li> </ul>	ccording to IEC 60947-4-1	Yes			
<ul> <li>positively driven</li> </ul>	operation according to IEC	C 60947-5-1 No			
-	y-related switching OFF	Yes			
B10 value with high de	emand rate according to SN	1 00	0 000		
proportion of danger	ous failures				
<ul> <li>with low demand</li> </ul>	d rate according to SN 319	20 40 %	6		
<ul> <li>with high demar</li> </ul>	nd rate according to SN 319	920 73 %	6		
failure rate [FIT] with lo	ow demand rate according	to SN 31920 100	FIT		
	interval or service life acco	ording to IEC 20 a	I		
61508					
•	n the front according to I				
•	the front according to IEC	<b>60529</b> finge	er-safe, for vertical contact	from the front	
ertificates/ approvals					
General Product App	oroval				
	Confirmation			KC	
(SP)		(m)	<i>(</i> Ui)		C 0 F
<b>U</b>					СПГ
CSA		ccc	UL		
EMC	Functional Safety/Safety of Ma-	Declaration of Confo	ormity	Test Certificates	
Lino	chinery		, intro		
<b>A</b>	Type Examination Cer-	~ ~	UK	Type Test Certific-	Special Test Certific
<b>K</b> A	tificate	(		ates/Test Report	ate
ксм Marine / Shipping		EG-Konf.	Сн		
Marine / Shipping		EG-Konf.	Llovds Register		
Marine / Shipping	BUREAU VERITAS	EG-Konf.		PRS	RINA
Marine / Shipping	BUREAU VERITAS	JÅ DNV	Lloyds Register	PRS Dangerous Good	<b>Environment</b>
ABS	VERITAS	JÅ DNV	Llovdis Register urs	PRS Dangerous Good	RINA Environment
ABS	VERITAS	JÅ DNV	Llovdis Register urs	PRS Dangerous Good <u>Transport Information</u>	Environmental Cor
ABS	other		Lins Railway	Ū	
ABS	other		Lins Railway	Ū	Environmental Cor
ABS	other		Lins Railway	Ū	Environmental Cor
ABS	other		Lins Railway	Ū	Environmental Cor
ABS Marine / Shipping	other		Lins Railway	Ū	Environmental Cor
ABS Marine / Shipping Warine kipping	VERITAS Other Confirmation	Confirmation	Lins Railway	Ū	Environmental Cor
ABS Marine / Shipping Warine / Shipping Marine / Shipping	other	Confirmation	Liks Railway Vibration and Shock	Ū	Environmental Cor
ABS Marine / Shipping Warine / Shipping Warine / Shipping Warine / Shipping Marine / Shipping Marine / Shipping Siemens has decided Siemens has decided Siemens has decided	veritas         other         Confirmation         d to exit the Russian mark         com/global/en/pressrelease         on the renewal of the curr	Confirmation	Railway Vibration and Shock	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Warine / Shipping Warine / Shipping Warine / Shipping Marine / Shipping Warine / Shipping Marine / Shipping	to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s	Confirmation	Railway Vibration and Shock Ssian-business AC certification if you interview	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine /	veritas         other         Confirmation         d to exit the Russian mark         com/global/en/pressrelease         on the renewal of the curr         cal Siemens office on the so         other than the sanctioned B         ackaging	Confirmation Confirmation	Railway Vibration and Shock Ssian-business AC certification if you interview	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine /	veritas         other         Confirmation         d to exit the Russian mark         com/global/en/pressrelease         on the renewal of the curr         cal Siemens office on the so         other than the sanctioned B         ackaging         v.siemens.com/cs/ww/en/vi	Confirmation Confirmation Ket (see here). Siemens-wind-down-rus ent EAC certificates. tatus of validity of the EA EAEU member states Ru ew/109813875	Railway Vibration and Shock Ssian-business AC certification if you interview	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine /	verifield         other         Confirmation         d to exit the Russian mark         com/global/en/pressrelease         on the renewal of the curr         cal Siemens office on the s         other than the sanctioned B         ackaging         v.siemens.com/cs/ww/en/vi         vnloadcenter (Catalogs, E	Confirmation Confirmation Ket (see here). Siemens-wind-down-rus ent EAC certificates. tatus of validity of the EA EAEU member states Ru ew/109813875	Railway Vibration and Shock Ssian-business AC certification if you interview	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine /	VERITAS           other           Confirmation           d to exit the Russian mark           com/global/en/pressrelease           on the renewal of the curr           cal Siemens office on the s           other than the sanctioned B           ackaging           visiemens.com/cs/ww/en/vision           wnloadcenter (Catalogs, B	Confirmation Confirmation Ket (see here). Siemens-wind-down-rus ent EAC certificates. tatus of validity of the EA EAEU member states Ru ew/109813875	Railway Vibration and Shock Ssian-business AC certification if you interview	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine /	to exit the Russian mark confirmation d to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s other than the sanctioned B ackaging /.siemens.com/cs/ww/en/vi wnloadcenter (Catalogs, B com/ic10 ordering system) emens.com/mall/en/en/Cata	Confirmation Confirmation confirmation cet (see here). cent EAC certificates. tatus of validity of the EA EAEU member states Ru cew/109813875 Brochures,)	Railway Vibration and Shock	Transport Information	Environmental Cor firmations
Marine / Shipping Marine / Ship	to exit the Russian mark confirmation d to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s other than the sanctioned B ackaging siemens.com/cs/ww/en/vii wnloadcenter (Catalogs, B com/ic10 ordering system) emens.com/mall/en/en/Cata	Confirmation confir	Railway Vibration and Shock	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine / Shipping Wither information Siemens has decided https://press.siemens.co Siemens is working of Please contact your loo EAC relevant market (in nformation on the pa https://support.industry information - and Dow inttps://www.siemens.co ndustry Mall (Online https://www.siemens.co ndustry Mall (Online https://support.automati	to exit the Russian mark confirmation d to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s other than the sanctioned B ackaging siemens.com/cs/ww/en/vii wnloadcenter (Catalogs, B com/ic10 ordering system) emens.com/mall/en/en/Catalogs	Confirmation Confirmation Confirmation confi	Railway Vibration and Shock	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine / S	to exit the Russian mark confirmation d to exit the Russian mark com/global/en/pressrelease on the renewal of the curr cal Siemens office on the s other than the sanctioned B ackaging siemens.com/cs/ww/en/vii wnloadcenter (Catalogs, B com/ic10 ordering system) emens.com/mall/en/en/Cata	Confirmation Confirmation Confirmation confi	Railway Vibration and Shock	Transport Information	Environmental Cor firmations
ABS Marine / Shipping Marine /	verifies           other           Confirmation           d to exit the Russian mark           com/global/en/pressrelease           on the renewal of the curr           cal Siemens office on the sanctioned B           ackaging           /.siemens.com/cs/ww/en/vi           vnloadcenter (Catalogs, B           condring system)           emens.com/mall/en/en/catalogs, B           ion.siemens.com/www.catalogs, Catalogs, B           ordering system)           emens.com/mall/en/en/catalogs, B           vnloadcenter (Catalogs, B           condition, Siemens.com/cs/ww/en/vi           vnloadcenter (Catalogs, B           condition, Siemens.com/cs/ww/en/vi           out images, 2D dimension	Confirmation Confi	Railway         Vibration and Shock         Ssian-business         AC certification if you intensisia or Belarus).         038-1AN24         een&mlfb=3RT2038-1AN22         s, device circuit diagram	Transport Information d to import or offer to supp	Environmental Cor firmations
ABS Marine / Shipping Marine /	VERITAS           other           Confirmation           d to exit the Russian mark           com/global/en/pressrelease           on the renewal of the curr           cal Siemens office on the s           other than the sanctioned B           ackaging           /.siemens.com/cs/ww/en/vi           wnloadcenter (Catalogs, B           com/global/en/pressrelease           ion.siemens.com/cs/ww/en/vi           wnloadcenter (Catalogs, B           com/c10           ordering system)           emens.com/mall/en/en/Cata           ion.siemens.com/cs/ww/en/pr           duct images, 2D dimensio           siemens.com/cs/ww/en/pr	Confirmation Confi	Railway         Vibration and Shock         Ssian-business         AC certification if you intensisia or Belarus).         038-1AN24         een&mlfb=3RT2038-1AN22         s, device circuit diagram	Transport Information d to import or offer to supp	Environmental Cor firmations
ABS Marine / Shipping Marine / Shipping Warine / Shipping Ther information tips://press.siemens.c. Siemens has decided tips://press.siemens.c. Siemens is working of Please contact your lo EAC relevant market (in formation on the pa tips://support.industry information - and Dow tips://www.siemens.c. ndustry Mall (Online tips://support.industry information - and Dow tips://support.industry service&Support (Ma tips://support.industry mage database (proo tip://www.automation Characteristic: Trippi	verifies           other           Confirmation           d to exit the Russian mark           com/global/en/pressrelease           on the renewal of the curr           cal Siemens office on the sanctioned B           ackaging           /.siemens.com/cs/ww/en/vi           vnloadcenter (Catalogs, B           condring system)           emens.com/mall/en/en/catalogs, B           ion.siemens.com/www.catalogs, Catalogs, B           ordering system)           emens.com/mall/en/en/catalogs, B           vnloadcenter (Catalogs, B           condition, Siemens.com/cs/ww/en/vi           vnloadcenter (Catalogs, B           condition, Siemens.com/cs/ww/en/vi           out images, 2D dimension	Confirmation Confi	Railway         Vibration and Shock         Ssian-business         AC certification if you intensisia or Belarus).         038-1AN24         een&mlfb=3RT2038-1AN22         s, device circuit diagram	Transport Information d to import or offer to supp	Environmental Cor firmations

 $\underline{http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RT2038-1AN24\&objecttype=14\&gridview=view1$ 





last modified:

8/15/2023 🖸

3RT20381AN24 Page 7/8

8/17/2023

Subject to change without notice © Copyright Siemens

## **Mouser Electronics**

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 3RT20381AN24