## SIEMENS

## Data sheet


## 3TH4280-0AG2



Contactor relay, 80E, DIN EN 50011, 8 NO, screw terminal AC operation 110 V AC 50/60 Hz

product designation	Auxiliary contactor		
product type designation	3TH4		
size of contactor	0		
reference code according to IEC 81346-2	К		
Substance Prohibitance (Date)	12/31/2099		
ambient temperature during operation	-25 +55 °C		
type of voltage of the control supply voltage	AC		
control supply voltage at AC			
• at 50 Hz rated value	110 V		
• at 60 Hz rated value	110 V		
control supply voltage frequency			
• 1 rated value	50 Hz		
• 2 rated value	60 Hz		
number of NC contacts for auxiliary contacts	0		
<ul> <li>delayed switching</li> </ul>	0		
<ul> <li>lagging switching</li> </ul>	0		
<ul> <li>make-before-break switching</li> </ul>	0		
number of NO contacts for auxiliary contacts	8		
<ul> <li>delayed switching</li> </ul>	0		
<ul> <li>leading contact</li> </ul>	0		
<ul> <li>make-before-break switching</li> </ul>	0		
number of CO contacts for auxiliary contacts	0		
identification number and letter for switching elements	80 E		
operational current at AC-15			
• at 230 V rated value	10 A		
• at 400 V rated value	6 A		
fastening method	screw and snap-on mounting onto 35 mm DIN rail accord	ding to DIN EN 50022	
height	78 mm		
width	45 mm		
depth	102 mm		
type of electrical connection for auxiliary and control circuit	screw-type terminals		
Safety related data			
B10 value with high demand rate according to SN 31920	1 000 000; With 0.3 x le		
T1 value for proof test interval or service life according to IEC 61508	20 a		
protection class IP on the front according to IEC 60529	IP00		
Certificates/ approvals			
General Product Approval		Functional Safety/Safety of Ma- chinery	

(SP)			KC	EHC	<u>Type Examination Cer-</u> <u>tificate</u>	
Declaration of Confo	ormity	Test Certificates				
C C EG-Konf.	UK CA	Type Test Certific- ates/Test Report	<u>Special Test Certific-</u> <u>ate</u>	<u>Miscellaneous</u>	<u>Miscellaneous</u>	
Marine / Shipping	other	Railway				
DNV-GL EM/SLCDED	<u>Confirmation</u>	<u>Special Test Certific-</u> <u>ate</u>				
Further information Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business Siemens is working on the renewal of the current EAC certificates. Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).						
Information on the packaging <u>https://support.industry.siemens.com/cs/ww/en/view/109813875</u> Information- and Downloadcenter (Catalogs, Brochures,)						
https://www.siemens.com/ic10 Industry Mall (Online ordering system) https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3TH4280-0AG2						
Service&Support (Ma https://support.industry	on.siemens.com/WW/CA anuals, Certificates, Cha v.siemens.com/cs/ww/en/p	os/3TH4280-0AG2	en&mlfb=3TH4280-0AG2	EPLAN macros)		
http://www.automation Characteristic: Trippi		de.aspx?mlfb=3TH4280-0 et-through current		, <u>_</u> , <u>_</u> , <u>,</u> , <u>,</u> , <u>,</u> , <u>,</u> , <u>,</u> , <u>,</u>		
Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3TH4280-0AG2&objecttype=14&gridview=view1						



last modified:

11/21/2022 🖸

## **Mouser Electronics**

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 3TH42800AG2