SIEMENS

Data sheet

3TH4394-0AD0



Contactor relay, 55E, EN 50011, 5 NO + 5 NC, 1U, screw terminal 42 V AC 50 Hz/50 V AC 60 Hz AC operation,

product designation	Auxiliary contactor		
product type designation	3TH4		
size of contactor	0		
reference code according to IEC 81346-2	К		
Substance Prohibitance (Date)	12/31/2099		
ambient temperature during operation	-25 +55 °C		
type of voltage of the control supply voltage	AC		
control supply voltage at AC			
• at 50 Hz rated value	42 V		
• at 60 Hz rated value	50 V		
control supply voltage frequency			
• 1 rated value	50 Hz		
2 rated value	60 Hz		
number of NC contacts for auxiliary contacts	4		
 delayed switching 	0		
 lagging switching 	1		
 make-before-break switching 	1		
number of NO contacts for auxiliary contacts	4		
 delayed switching 	0		
leading contact	1		
 make-before-break switching 	1		
number of CO contacts for auxiliary contacts	0		
identification number and letter for switching elements	55 E, 1U		
operational current at AC-15			
• at 230 V rated value	10 A		
• at 400 V rated value	6 A		
fastening method	screw and snap-on mounting o	nto 35 mm DIN rail accore	ding to DIN EN 50022
height	78 mm		
width	55 mm		
depth	102 mm		
type of electrical connection for auxiliary and control circuit	screw-type terminals		
Safety related data			
B10 value with high demand rate according to SN 31920	1 000 000; With 0.3 x le		
T1 value for proof test interval or service life according to IEC 61508	20 a		
protection class IP on the front according to IEC 60529	IP00		
Certificates/ approvals			
General Product Approval		Functional Safety/Safety of Ma- chinery	Declaration of Con- formity

(SP)			EHC	<u>Type Examination Cer-</u> tificate	CE EG-Konf.	
Declaration of Con- formity	Test Certificates				Marine / Shipping	
UK CA	Type Test Certific- ates/Test Report	<u>Miscellaneous</u>	<u>Special Test Certific-</u> <u>ate</u>	<u>Miscellaneous</u>	DNV-GL DNV-GL	
other	Railway					
<u>Confirmation</u>	<u>Special Test Certific-</u> <u>ate</u>					
Further information						
Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business Siemens is working on the renewal of the current EAC certificates. Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an						

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

all.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3TH4394-0AD0 https://n

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3TH4394-0AD0

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3TH4394-0AD0


Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3TH4394-0AD0&lang=en

Characteristic: Tripping characteristics, I²t, Let-through current

https://support.industry.siemens.com/cs/ww/en/ps/3TH4394-0AD0/char

Further characteristics (e.g. electrical endurance, switching frequency) http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3TH4394-0AD0&objecttype=14&gridview=view1





last modified:

11/21/2022 🖸

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 3TH43940AD0