# SIEMENS

#### Data sheet

### 5SJ4140-6HG40



Miniature circuit breaker 240 V 14kA, 1-pole, B, 40A, D=70 mm according to UL 489, equal polarity

Model							
product brand name	SENTRON						
product designation	Miniature circuit breakers						
design of the product	Miniature circuit-breaker 5SJ4						
General technical data							
number of poles	1						
design of pole	1P						
tripping characteristic class	В						
mechanical service life (operating cycles) typical	10 000						
installation environment regarding EMC	Suitable for environment B (immunity to interference not applicable)						
reference code according to DIN 40719 extended according to IEC 204-2 according to IEC 750	F						
overvoltage category	3						
degree of pollution	3						
Voltage							
insulation voltage (Ui) at AC rated value	440 V						
Supply voltage							
supply voltage							
at AC rated value	400 V						
at DC rated value	60 V						
value range of the supply voltage frequency	50/60 Hz						
operating voltage							
<ul> <li>at AC according to UL 489 and CSA C22.2 No. 5-02 maximum</li> </ul>	120 V						
<ul> <li>at DC rated value maximum</li> </ul>	60 V						
<ul> <li>at DC single channel according to UL 489 and CSA C22.2 No. 5-02 maximum</li> </ul>	60 V						
supply voltage frequency rated value	50 Hz						
Protection class							
protection class IP	IP20, with connected conductors, IP 40 in the handle range						
Switching capacity							
switching capacity current							
<ul> <li>according to EN 60898 rated value</li> </ul>	10 kA						
<ul> <li>according to IEC 60947-2 rated value</li> </ul>	15 kA						
Dissipation							
power loss [W] for rated value of the current at AC in hot operating state per pole	4.8 W						
Main circuit							
type of voltage supply at AC according to UL 489 and CSA C22.2 No. 5-02	240/120						
suitability for operation	Mechanical engineering / industry						

Subject to change without notice © Copyright Siemens

Product details							
product component							
<ul> <li>tunnel terminals top</li> </ul>			No				
<ul> <li>tunnel terminals botto</li> </ul>	om		No				
<ul> <li>combined terminal to</li> </ul>	p		Yes				
<ul> <li>combined terminal bo</li> </ul>	ottom		Yes				
<ul> <li>neutral conductor sw</li> </ul>	itching		No				
product feature							
<ul> <li>halogen-free</li> </ul>			Yes				
sealable			Yes				
<ul> <li>silicon-free</li> </ul>			Yes				
product extension installable	e supplementary devic	ces	Yes				
Product function			1.00				
product function note			Terminal t	ightening torque fo	or Cu, 60/75°C; 3.5Nm/31lb.i	n	
Short circuit		_	Terriniari		i Cu, 00/75 C, 5.5Niii/5115.		
short-circuit current breakin UL 1077 and CSA C22.2 No		according to	14 kA				
Connections							
connectable conductor cros end processing	s-section finely strand	led with core					
<ul> <li>minimum</li> </ul>			0.75 mm <sup>2</sup>				
<ul> <li>maximum</li> </ul>			25 mm²				
tightening torque with screw	v-type terminals maxin	num	3.5 N·m				
position of power supply co	rd		Any				
Mechanical Design							
height			90 mm				
width			18 mm				
depth			70 mm				
installation depth			70 mm				
number of modular width ur	nits		1				
fastening method			on standard mounting rail				
mounting position			any				
net weight			167 g				
Environmental conditions							
standard			IEC / EN 6	0947-2 / UL 489			
vibration resistance			50 m/s <sup>2</sup> at 25 to 150Hz and 60m/s <sup>2</sup> at 35Hz (4sec)				
vibration resistance accordi	ng to IEC 60068-2-6		±1 mm at 5 to 25 Hz; 50 m/s² at 25 to 150 Hz				
ambient temperature during	-			,			
• minimum	opolation		55 °C				
maximum			-25 °C				
ambient temperature during	operation		max. 95% humidity				
ambient temperature during			max. 5570	namony			
<ul> <li>minimum</li> </ul>	lologo		-40 °C				
maximum			-40°C 75 °C				
General Product Approva			15 0		Declaration of Confor	mity	
General Floduct Applova					Declaration of Como	iiity	
	Confirmation	$\sim$					
( <b>m</b> )		(U <sub>I</sub> )		FAL	CE	UK	
				ENL		UK CA	
CCC		UL			EG-Konf.		
T		- 41			E		
Test Certificates		other			Environment		
Miscellaneous S	pecial Test Certific- ate	<b>Confirmation</b>		Miscellaneous	Environmental Con-		

firmations

Further information

Siemens has decided to exit the Russian market (see here). https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

<u>ate</u>

#### Siemens is working on the renewal of the current EAC certificates.

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus). Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SJ4140-6HG40

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SJ4140-6HG40

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=5SJ4140-6HG40

CAx-Online-Generator

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications



last modified:

8/13/2023 🖸

## **Mouser Electronics**

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 5SJ41406HG40