## SIEMENS

## Data sheet

## 6EP3233-0TA10-0AY0



SITOP PSU3400/DC/DC/48V/24V/3.5A

SITOP PSU3400 24 V/3.5 A Stabilized power supply Input: 48 V DC (28...60 V) Output: 24 V DC/3.5 A NEC CLASS2

Input	
type of the power supply network	DC voltage
supply voltage at AC	
initial value	Startup as of 36 V, derating necessary for 28 36 V DC
supply voltage	
• at DC	48 48 V
input voltage	
• at DC	28 60 V
design of input wide range input	No
overvoltage overload capability	-
operating condition of the mains buffering	at Vin = 48 V
buffering time for rated value of the output current in the event of power failure minimum	5 ms
operating condition of the mains buffering	at Vin = 48 V
input current	
<ul> <li>at rated input voltage 48 V</li> </ul>	1.9 A
current limitation of inrush current at 25 °C maximum	15 A
I2t value maximum	0.09 A <sup>2</sup> ·s
fuse protection type	15 A (not accessible), breaking capacity 100 A
• in the feeder	Recommended miniature circuit breaker: 16 A characteristic B or C
Output	
voltage curve at output	Controlled, isolated DC voltage
output voltage at DC rated value	24 V
output voltage	
<ul> <li>at output 1 at DC rated value</li> </ul>	24 V
relative overall tolerance of the voltage	1 %
relative control precision of the output voltage	
<ul> <li>on slow fluctuation of input voltage</li> </ul>	0.1 %
<ul> <li>on slow fluctuation of ohm loading</li> </ul>	0.2 %
residual ripple	
• maximum	150 mV
• typical	30 mV
voltage peak	
• maximum	250 mV
● typical	70 mV
adjustable output voltage	24 28 V
product function output voltage adjustable	Yes
type of output voltage setting	via potentiometer
display version for normal operation	Green LED for 24 V OK
behavior of the output voltage when switching on	No overshoot of Vout (soft start)

response delay maximum	0.5 s
voltage increase time of the output voltage	
• typical	10 ms
• maximum	20 ms
output current	
<ul> <li>rated value</li> </ul>	3.5 A
rated range	0 3.5 A; +60 to +70 °C: without derating
supplied active power typical	91 W
product feature	
<ul> <li>bridging of equipment</li> </ul>	Yes
number of parallel-switched equipment resources for increasing	2
the power	
Efficiency	
efficiency in percent	90 %
power loss [W]	
<ul> <li>at rated output voltage for rated value of the output</li> </ul>	7 W
current typical	
during no-load operation maximum	1.5 W
Closed-loop control	
relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical	0.3 %
	2 %
relative control precision of the output voltage load step of resistive load 50/100/50 % typical	∠ /0
setting time	
<ul> <li>load step 50 to 100% typical</li> </ul>	1 ms
<ul> <li>load step 100 to 50% typical</li> </ul>	1 ms
Protection and monitoring	
design of the overvoltage protection	Ua < 35 V
typical	3.8 A
	Yes
property of the output short-circuit proof	
design of short-circuit protection	Electronic shutdown, automatic restart
display version for overload and short circuit Safety	LED yellow for "overload"
	Vec
actuation inclution hot upon input and output	
galvanic isolation between input and output	Yes
galvanic isolation	Safety extra low output voltage Vout according to EN 60950-1
galvanic isolation operating resource protection class	Safety extra low output voltage Vout according to EN 60950-1 Class III
galvanic isolation operating resource protection class protection class IP	Safety extra low output voltage Vout according to EN 60950-1
galvanic isolation operating resource protection class protection class IP Approvals	Safety extra low output voltage Vout according to EN 60950-1 Class III
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No
galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No Yes
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No Yes Yes
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval         • Regulatory Compliance Mark (RCM)	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No Yes Yes
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval         • Regulatory Compliance Mark (RCM)         certificate of suitability shipbuilding approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No Yes Yes
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval         • Regulatory Compliance Mark (RCM)         certificate of suitability shipbuilding approval	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No Yes Yes
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval         • Regulatory Compliance Mark (RCM)         certificate of suitability shipbuilding approval         shipbuilding approval         Marine classification association         • American Bureau of Shipping Europe Ltd. (ABS)	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No Yes Yes Yes Yes Yes ABS, DNV GL
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval         • Regulatory Compliance Mark (RCM)         certificate of suitability shipbuilding approval         shipbuilding approval         Marine classification association         • American Bureau of Shipping Europe Ltd. (ABS)         • French marine classification society (BV)	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No No Yes Yes Yes Yes Yes Yes Yes NoS
galvanic isolation         operating resource protection class         protection class IP         Approvals         certificate of suitability         • CE marking         • UL approval         • CSA approval         • cCSAus, Class 1, Division 2         • ATEX         certificate of suitability         • IECEx         • NEC Class 2         • ULhazloc approval         • FM registration         type of certification CB-certificate         certificate of suitability         • EAC approval         • Regulatory Compliance Mark (RCM)         certificate of suitability shipbuilding approval         shipbuilding approval         Marine classification association         • American Bureau of Shipping Europe Ltd. (ABS)	Safety extra low output voltage Vout according to EN 60950-1 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259 No No No No No No Yes Yes Yes Yes Yes Yes Yes

ЕМС	
standard	
<ul> <li>for emitted interference</li> </ul>	EN 61000-6-3
<ul> <li>for mains harmonics limitation</li> </ul>	not applicable
<ul> <li>for interference immunity</li> </ul>	EN 61000-6-2
environmental conditions	
ambient temperature	
during operation	-25 +70 °C; with natural convection
during transport	-40 +85 °C
during storage	-40 +85 °C
environmental category according to IEC 60721	Climate class 3K3, 5 95% no condensation
Mechanics	
type of electrical connection	screw-type terminals
• at input	L, N, FE: 1 screw terminal each for 0.5 2.5 mm² single-core/finely stranded
at output	+, -: 2 screw terminals each for 0.5 2.5 mm <sup>2</sup>
width of the enclosure	32 mm
height of the enclosure	100 mm
depth of the enclosure	100 mm
required spacing	
• top	50 mm
bottom	50 mm
• left	0 mm
• right	0 mm
net weight	0.32 kg
product feature of the enclosure housing can be lined up	Yes
fastening method	Snaps onto DIN rail EN 60715 35x7.5/15
electrical accessories	Buffer module
MTBF at 40 °C	1 934 648 h
other information	Specifications at rated input voltage and ambient temperature +25 $^\circ \rm C$ (unless otherwise specified)

Ø

## **Mouser Electronics**

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 6EP32330TA100AY0