SIEMENS

Data sheet

6EP4436-8XB00-0CY0



SITOP CNX8600 4x5 A expansion module for PSU8600 output: 24 V DC/4x 5 A *Ex approval no longer available*

SITOP CNX8600/4X5A

Output	
voltage curve at output	Controlled, isolated DC voltage
number of outputs	4
output voltage at DC rated value	24 V
output voltage	
 at output 1 at DC rated value 	24 V
 at output 2 at DC rated value 	24 V
 at output 3 at DC rated value 	24 V
 at output 4 at DC rated value 	24 V
relative overall tolerance of the voltage	3 %
relative control precision of the output voltage	
 on slow fluctuation of input voltage 	0.2 %
 on slow fluctuation of ohm loading 	0.1 %
residual ripple	
• maximum	100 mV
voltage peak	
• maximum	200 mV
adjustable output voltage	4 28 V
product function output voltage adjustable	Yes
type of output voltage setting	via potentiometer or IE/PN interface; Derating > 24 V: 4%/V; max. 120 W per output
display version for normal operation	3-color LED for operating state module; 3-color LED per output for operating state output
type of signal at output	Relay contact (changeover contact, contact current capacity DC 60 V/0.3 A) for "Operating state OK" at power supply unit PSU8600
behavior of the output voltage when switching on	No overshoot of Vout (soft start)
response delay maximum	1.5 s; Without on-delay of the outputs
type of outputs connection	Simultaneous connecting-in of all outputs after device booting or delay time of 25 ms, 100 ms or "load-optimized" for sequential cutting-in of the outputs via DIP switches at power supply unit PSU8600 can be set
voltage increase time of the output voltage	
• maximum	500 ms
output current	
rated value	20 A
• per output	5 A
 at output 1 rated value 	5 A
 at output 2 rated value 	5 A
 at output 3 rated value 	5 A
 at output 4 rated value 	5 A
rated range	0 20 A; No increase in the maximum output power of the overall system SITOP PSU8600 via the expansion module SITOP CNX8600 possible
supplied active power typical	480 W

naduat facture	
product feature	Na
parallel switching of outputs	No
 bridging of equipment 	No
Efficiency	
efficiency in percent	97 %
power loss [W]	
 at rated output voltage for rated value of the output current typical 	15 W
Closed-loop control	
relative control precision of the output voltage with rapid fluctuation of the input voltage by +/- 15% typical	0.1 %
relative control precision of the output voltage load step of resistive load 50/100/50 % typical	0.4 %
setting time	
• maximum	10 ms
Protection and monitoring	
design of the overvoltage protection	max. 35 V (max. 500 ms)
property of the output short-circuit proof	Yes
design of short-circuit protection	electronic overload cut-off
adjustable current response value current of the current- dependent overload release	0.5 5 A
type of response value setting	via potentiometer or IE/PN interface
switching characteristic	
• of the excess current	la >1.0<1.5 x la threshold permissible for 5 s; la limit (= 1.5 x la threshold) permissible for 200 ms
design of the reset device/resetting mechanism	via sensor per output or IE/PN interface
remote reset function	Non-electrically isolated 24 V input (signal level "high" at > 15 V) at power supply unit PSU8600
display version for overload and short circuit	3-color LED for operating state module; 3-color LED per output for operating state output
Interface	
design of the interface	Ethernet/PROFINET via power supply unit PSU8600
Safety	
Safety	Yes
Safety galvanic isolation between input and output	Yes
Safety galvanic isolation between input and output galvanic isolation	
Safety galvanic isolation between input and output galvanic isolation operating resource protection class	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1)
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No No No No No Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certificate of suitability • EAC approval	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No No Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • UL hazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No Yes Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No Yes Yes Yes Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No Yes Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability shipbuilding approval shipbuilding approval	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No Yes Yes Yes ABS, DNV GL
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability shipbuilding approval shipbuilding approval Marine classification association • American Bureau of Shipping Europe Ltd. (ABS)	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No No Yes Yes Yes ABS, DNV GL Yes Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability shipbuilding approval shipbuilding approval Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV)	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No No Yes Yes ABS, DNV GL Yes No
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • CSA approval • CSA approval • CSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability • EAC approval • C-Tick certificate of suitability shipbuilding approval shipbuilding approval Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV) • DNV GL	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No Yes Yes Yes Yes Yes No No Yes Yes Yes Yes Yes Yes Yes No Yes No Yes ABS, DNV GL Yes No Yes
Safety galvanic isolation between input and output galvanic isolation operating resource protection class protection class IP Approvals certificate of suitability • CE marking • UL approval • CSA approval • cCSAus, Class 1, Division 2 • ATEX certificate of suitability • IECEx • NEC Class 2 • ULhazloc approval • FM registration type of certification CB-certificate certificate of suitability • EAC approval • C-Tick certificate of suitability shipbuilding approval shipbuilding approval Marine classification association • American Bureau of Shipping Europe Ltd. (ABS) • French marine classification society (BV)	Yes Safety extra-low output voltage Uout acc. to EN 60950-1 and EN 50178 Class III IP20 Yes Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) Yes; cULus-Listed (UL 508, CSA C22.2 No. 107.1), File E197259; cCSAus (CSA C22.2 No. 60950-1, UL 60950-1) No No No No No Yes Yes ABS, DNV GL Yes No

EMC	
standard	
 for emitted interference 	EN 55022 Class B
 for interference immunity 	EN 61000-6-2
environmental conditions	
ambient temperature	
during operation	-25 +60 °C; with natural convection
 during transport 	-40 +85 °C
during storage	-40 +85 °C
environmental category according to IEC 60721	Climate class 3K3, 5 95% no condensation
Mechanics	
type of electrical connection	Plug-in terminals with screwed connection
• at output	1, 2, 3, 4: Two plug-in terminals (1, 2 and 3, 4) with 2 screwed connections each for 0.2 2.5 mm ² ; Ground: Plug-in terminal with 3 screwed connections for 0.2 2.5 mm ²
product function	
 removable terminal at output 	Yes
suitability for interaction modular system	Yes
type of connection to system components	Via integrated connector
width of the enclosure	60 mm
height of the enclosure	125 mm
depth of the enclosure	150 mm
required spacing	
• top	50 mm
• bottom	50 mm
• left	0 mm
• right	0 mm
net weight	1.15 kg
product feature of the enclosure housing can be lined up	Yes
fastening method	Snaps onto DIN rail EN 60715 35x15
mechanical accessories	Device identification label 20 mm × 7 mm, TI-grey 3RT2900-1SB20
MTBF at 40 °C	358 372 h
other information	Specifications at rated input voltage and ambient temperature +25 $^\circ\text{C}$ (unless otherwise specified)

C

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Siemens: 6EP44368XB000CY0