

7 > CONDITION OF SAFETY STANDARD(UL, C-UL, TUV STANDARD)

 $2 \times M6 \times 1$

7> FIG1. PANEL CUTOUT




TABLE 1. UL, C-UL CONDITION

	CONDITION 1	CONDITION 2	
CURRENT VOLTAGE(AC/DC)	600V		
CURRENT RATING	100A	150A	
CABLE	14 TO 22sq(※1)	38 TO 50sq(% 1)	
CREEPAGE DISTANCE(※2)	MIN:3.2mm		
CLEARANCE DISTANCE(※2)	MIN:3.2mm		

TABLE 2. TUV CONDITON

	CONDITION I	CONDITION II	
CURRENT VOLTAGE(AC/DC)	800V	600V	
	100A(CABLE 14	1 TO 22sq % 1)	
CURRENT RATING	125A(CABLE 38sq ※1)		
	150A(CABLE 50)sq ※ 1)	
OVER VOLTAGE CATEGORY	II	Ш	
POLLUTION DEGREE	3		
CREEPAGE DISTANCE(※2)	MIN:12.6mm	MIN:12.6mm	
CLEARANCE DISTANCE(%2)	MIN:6mm	MIN:6mm	
INSULATION SYSTEM	BASIC INSULATION		
	(PANEL HAS THE EARTH)		

TABLE 3. TUV CONDITON

	CONDITION III	
CURRENT VOLTAGE(AC/DC)	1000V	
	100A(CABLE 14 TO 22sq 涨1)	
CURRENT RATING	125A(CABLE 38sq ※1)	
	150A(CABLE 50sq ※1)	
OVER VOLTAGE CATEGORY	Ш	
POLLUTION DEGREE	3	
CREEPAGE DISTANCE(※2)	MIN:16mm	
CLEARANCE DISTANCE(%2)	MIN:8mm	
INSULATION SYSTEM	BASIC INSULATION	
	(PANEL HAS THE EARTH)	

**1: AS SCREWS AND CRIMP TERMINAL ATTACHED WITH POWER CONTACT HAVE AN IMPACT ON THE CREEPAGE DISTANCE AND THE CLEARANCE DISTANCE, PLEASE USE RECOMMENDED SCREWS AND CRIMP TERMINALS. IN CASE YOU USE CABLES OTHER THAN FOLLOWING RECOMMENDED SCREWS AND CONTACTS, PLEASE BE CAREFUL THAT THE CREEPAGE DISTANCE AND THE CLEARANCE DISTANCE MEET THE STANDARD OF UL, C-UL, TUV.

№2: THE COVERAGE OF THE CREEPAGE DISTANCE AND THE CLEARANCE DISTANCE IS AS FOLLOWS.

-BETWEEN CRIMP TERMINALS

FORM HC0011-5-8 1

- -BETWEEN POWER CONTACT AND PANEL
- -BETWEEN CRIMP TERMINAL AND PANEL
- -BETWEEN SCREWS (ATTACEHD WITH POWER CONTACT) AND PANEL

φ÷ξ

※PANEL THICKNESS :3mm max.

7 FIG2. PANEL CUTOUT

119.5 ± 0.2

32. 45 $_{-1}^{0}$

44. 5 +0.5

48. 5 $^{+0.5}_{0}$

- 1. THE MATING PARTNER OF THIS PRODUCT IS PS3-2US(CL236-1041-0-00).
- 2>PLEASE SET THE DISTANCE BETWEEN PANELS AS 24.2 TO 26.2mm.
- 3>THE TIGHTINING TORQUE FOR THE SCREW ATTACHED WITH REF NO. ② IS 2.5 TO 5.2 N⋅m. THE RECOMMENDED SCREW AND TERMINAL IS AS FOLLOWS.
 - -RECCOMEDNED SCREW: JIS B 1188 SPRING WASHER + CROSS RECESSED PAN HEAD SCREW WITH CAPTIVE POLISHED CIRCULAR WASHER M6 imes 12
 - -RECOMMENDED CRIMP TERMINAL

CABLE 14sq : JIS C 2805 R14-6 CABLE 22sq : JIS C 2805 R22-6

CABLE 38sq : MANUFACTURED BY NICHIFU CO., LTD R38-6S CABLE 50sq : MANUFACTURED BY NICHIFU CO., LTD R60-6S

- THE SCREW USED TO ATTACH THE PANEL IS M6.
 THE TIGHTNING TORQUE FOR SCREW IS 2.5 TO 5.2 N·m.
- SINCE THE POWER CONTACTS ARE SILVER PLATED, THEY MAY REACT WITH SULFIDE IN THE ATOMOSPHER TO CHANGE THE COLOUR TO BLACKISH BROWN.
- 6. THE PRODUCT HAS FLOATING STRUCTURE WHICH CAN BE FLOATED 2.0 mm MAX. THE FLEXIBLE CABLE USED TO CONNECT WITH RECEPTACLE IS RECOMMENDED.
- THIS ITEM IS APPROVED BY SASFETY STANDARD(UL, C-UL, TUV STANDARD)
 IN CASE RECOMMENDED PANEL 1 SHOWN IN THE FIGURE 1 IS USED,
 APROVED BY THE CONDITION OF TABLE 1 AND TABLE 2.
 IN CASE RECOMMENDED PANEL 2 SHOWN IN THE FIGURE 2 IS USED,
 APROVED BY THE CONDITION OF TABLE 3.
 SAFETY STANDARD IS DEFERRENT UP TO THE APPLIED RATED VOLTAGE AND CURRENT PLEASE SEE THE TABLE 1 AND TABLE 2.

THE POWER CONTACT OF THIES PRODUCT IS NOT APPLICABLE FOR HOT-SWAP. IT CAN NOT BE USED TO INTERRUPT THE POWER.

	DRAWING NO.	EDC-128048-01-00	
HR5	PART NO.	PS3-2UP(01)	
CODE NO.		CL236-1042-2-01	\triangle $2/3$

Mouser Electronics

Authorized Distributor

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

Hirose Electric: PS3-2UP(01)