


## SE-400 SERIES

## Ground-Fault-Relay Test Unit



## **Simplified Circuit Diagram**



### **Description**

The SE-400 is a ground-fault-relay test unit designed to test current pickup level, time delay and coordination of ground-fault protection.

The tester injects current through the window of installed ground-fault current transformers to verify the operation of ground-fault monitors and relays.

It is used on substations, motor control centers (MCCs), central distribution panels, switchboards, and test benches to verify relay operation.

The SE-400 tests the entire ground-fault circuit including current transformers, wiring, ground-fault relay and the operation of the interrupting device. It is recommended to test every relay and its current interrupting device annually.

#### **Features & Benefits**

FEATURES	BENEFITS	
Adjustable Current Setpoint	Current range is 0.5 to 9.9 A	
Adjustable Time Duration Setpoint	Duration range is 0.1 to 9.9 s, or continuous output	
Small Form Factor	Lightweight and compact for portability	
Remote Test Input	Allows test to be initiated from another location	

## **Ordering Information**

ORDERING NUMBER	CONTROL POWER
SE-400	120 Vac

#### **Specifications**

Warranty

Mounting

Input Voltage 84-134 Vac, 50/60 Hz, 80 VA
Dimensions H 219 mm (8.6");
W 99 mm (3.9");
D 143 mm (5.6")

Output Current Settings 0.5-9.9 A
Output Duration Settings 0.1-9.9 s or continuous
Output Voltage 5.0 Vac maximum
Conformally Coated Standard feature

5 Year

Surface, Panel

© 2015 Littelfuse Protection Relays & Controls

Rev: 4-A-081515

Based on Manual Rev: 1-A-072115

# **Mouser Electronics**

**Authorized Distributor** 

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

# Littelfuse:

SE-400 SE-400-HDWR SE-400IRC SE-400-02