

# Hawk 3 Temperature Meter / Controller



- All parameters set from easy to understand front panel access
- One, two or four 5-amp relays optional
- 7-segment 4 digit red LED
- Five user-selectable brightness levels
- Activated set point indicators on display
- Min/Max and password lockout
- NEMA 4X rated front panel
- 4-20mA or 0-10 DCV analog retransmission optional
- 1/8 DIN, shallow depth case, 3.24"

Speci	fications -								
DISPLAY									
Туре		7- segment, red LED							
Height		0.56" (14.2mm)							
Brightness		5 settings, user programmable							
Overrange Indication		Display flashes "EEEE" indicating Maximum Value Exceeded							
Underrange Indication		Display flashes "-EEE" indicating Minimum Value Exceeded							
Resolution		1.0°							
Sensor Break		Display reads "EEEE"							
Excitation		100mA Max Current							
POWER REQUIREMENTS									
AC		85 to 250 VAC/120	OVAC @ 10VA						
DC 9 to 36 DCV @ 10VA									
	ACCURACY @ 25°C as % of rdg								
	Sensor Type	Accuracy	Temperature Range						
	RTD Pt 100	0.2% ± 2 counts	-200°C to +200°C						
J K		0.2% ± 2 counts	-100°C to +760°C						
		0.2% ± 2 counts	nts -200°C to +1250°C						
	E	0.2% ± 2 counts	-100°C to +800°C						
	Т	0.2% ± 2 counts	-200°C to +400°C						
			<u>'</u>						
		ENVIRONMEN	NTAL						
Operatir	ng Temperature	0 to 50°C							
Storage Temperature		-10 to +60°C							
Relative Humidity		< 80%							
Ambient Temp		25°C							
Temperature Drift		± 100 ppm /°C ± 0.05 dgt /°C							
Warmup time 10 minutes									
NOISE REJECTION									
NMRR		60 dB @ 50-60 Hz							
CMRR		100 db @ 50-60 Hz							
A TO D CONVERSION									
Techniq	ue	Successive approximation with oversampling							
Sample Rate		10 conversions per second							
Display	Rate	User Programmable from 1/minute - 8/seconds							
MECHANICAL									
Bezel 3.92" x 2.0" x 0.52" (99.8mm x 51.8mm x 132mm)									
Depth	. , , , .								
Panel cu	Panel cutout 3.62" x 1.77" (92mm x 45mm) 1/8 DIN								

10 oz. (283.5 g)

NEMA 4X Rated front panel

Weight


Cover



## Hawk 3 Temperature Meter / Controller


#### **Ordering Information -**

Hawk 3 Indicators can be configured by making an entry into each section. Example: H340-3-91-0-4-1



		Sele	ct From Each One I	Belo	)W		
Е	Basic Unit		Function/Range		5A Relays		
H340	4 Digit, Red LED	91	J Thermocouple	1 [	0	None	
		92	K Thermocouple	1 [	1	One	
Po	Power Supply		RTD, PT100 3-wire	1 [	2	Two	
1	120 ACV	94	E Thermocouple		4	Four	
3	9-36 DCV	95	T Thermocouple	1	'		
4	85-250 ACV			1 [	Excitation		
<u> </u>			Output	1 [	0	None	
		0	None		1	12 DCV - 100mA max current	
		1	4-20 DCmA	1	2	24 DCV - 100mA max current	
		2	0-10 DCV	1			

#### Installation and Panel Cutout - H335, H340, H345



#### **Engineering Label Placement**

To replace the engineering unit label, place the tip of a ballpoint pen into the small hole at the base of the engineering label in the bezel.


Slide the label up until it pops out. Grasp and remove. Slide the new label half the distance in, then use the ballpoint pen to slide it down into place.

#### **Mounting Requirements**

The Hawk 3 Advanced Digital Controller 1/8 DIN meters require a panel cutout of 1.77" (45mm) high by 3.62" (92mm) wide.

To install the Hawk 3 meter into a panel cutout, remove the clips from the side of the meter.

Slide the meter through the panel cutout, then slide the mounting clips back on the meter. Press evenly to ensure a proper fit. Tighten screws.



### **Mouser Electronics**

**Authorized Distributor** 

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

### Simpson:

H340191020 H340493010 H340491010