## SAFETY ORGANIZATION(S):

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET.

UL RECOGNIZED CSA CERTIFIED VDE APPROVED SEV APPROVED

UL 1283 CSA 22.2, NO.0,0.4,8 VDE 565-3 SEV 1055/TP1977/5.1.1

### OPERATING SPECIFICATIONS:

2 AMP, 120/250 VAC 2 AMP./40°C, 250 VAC LINE VOLTAGE/CURRENT.

LINE FREQUENCY, 50-60Hz

MAX. LEAKAGE CURRENT, EACH: LINE TO GROUND:

.25 mA AT 120V 60Hz .40 mA at 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C & RATED CURRENT, In

IN AN AMBIENT, Ta, HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, Io, IS AS FOLLOWS.

 $I_0 = I_r - \sqrt{85 - T_0}$ 

# 2ER1

## RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE. -40°C TO +85°C HUMIDITY. 21 DAYS @ 40°C 95% RH CURRENT OVERLOAD TEST: 6 TIMES RATED CURRENT FOR 8 SECONDS

#### TEST SPECIFICATIONS:

INDUCTANCE: 1.078 mH NOMINAL CAPACITANCE: (MEASURED @ 1 KHz, 0.25VAC MAX., 25°C±1°C) LINE TO GROUND: .006  $\mu$ F ±20% LINE TO LINE: .301  $\mu$ F ±20% DISCHARGE RESISTOR: 680Kn

LINE/GROUND AND LINE/LINE, 6000Ma (MIN) AT 100VDC INSULATION RESISTANCE, 20°C AND 50% RH


#### RECOMMENDED RECEIVING INSPECTION HIPOT:


LINES TO GROUND: LINE TO LINE.

2250 VDC FOR 1 MINUTE 1450 VDC FOR 1 MINUTE

# FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.







DATE: 9-28-93 CATALOG NO.

APPRVD. TAM 2ER1 2ER1.05

# **Mouser Electronics**

**Authorized Distributor** 

Click to View Pricing, Inventory, Delivery & Lifecycle Information:

TE Connectivity: 6609031-3