SIEMENS

Data sheet 3RT1056-6NP36



power contactor, AC-3e/AC-3 185 A, 90 kW / 400 V AC (50-60 Hz) / DC Uc: 200-277 V PLC input 24 V DC 3-pole, auxiliary contacts 2 NO + 2 NC drive: electronic main circuit: busbar control and auxiliary circuit: screw terminal

product brand name	SIRIUS
product designation	Power contactor
product type designation	3RT1
General technical data	
size of contactor	S6
product extension	
 function module for communication 	No
auxiliary switch	Yes
power loss [W] for rated value of the current	
 at AC in hot operating state 	39 W
 at AC in hot operating state per pole 	13 W
without load current share typical	2.8 W
type of calculation of power loss depending on pole	quadratic
insulation voltage	
 of main circuit with degree of pollution 3 rated value 	1 000 V
of auxiliary circuit with degree of pollution 3 rated value	500 V
surge voltage resistance	
of main circuit rated value	8 kV
of auxiliary circuit rated value	6 kV
maximum permissible voltage for protective separation between coil and main contacts according to EN 60947-1	690 V
shock resistance at rectangular impulse	
• at AC	8,5g / 5 ms, 4,2g / 10 ms
• at DC	8,5g / 5 ms, 4,2g / 10 ms
shock resistance with sine pulse	
• at AC	13,4g / 5 ms, 6,5g / 10 ms
• at DC	13,4g / 5 ms, 6,5g / 10 ms
mechanical service life (operating cycles)	
 of contactor typical 	10 000 000
 of the contactor with added electronically optimized auxiliary switch block typical 	5 000 000
of the contactor with added auxiliary switch block typical	10 000 000
reference code according to IEC 81346-2	Q
Substance Prohibitance (Date)	05/01/2012
SVHC substance name	Lead - 7439-92-1 Lead monoxide (lead oxide) - 1317-36-8 6,6'-di-tert-butyl-2,2'-methylenedi-p-cresol - 119-47-1
Weight	3.319 kg
Ambient conditions	
installation altitude at height above sea level maximum	2 000 m
ambient temperature	

during operation	-25 +60 °C
during storage	-55 +80 °C
relative humidity minimum	10 %
relative humidity at 55 °C according to IEC 60068-2-30 maximum	95 %
Main circuit	
number of poles for main current circuit	3
number of NO contacts for main contacts	3
operating voltage	
• at AC-3 rated value maximum	1 000 V
• at AC-3e rated value maximum	1 000 V
operational current	
• at AC-1 at 400 V at ambient temperature 40 °C rated value	215 A
• at AC-1	
— up to 690 V at ambient temperature 40 °C rated value	215 A
— up to 690 V at ambient temperature 60 °C rated value	185 A
— up to 1000 V at ambient temperature 40 °C rated value	100 A
 — up to 1000 V at ambient temperature 60 °C rated value ◆ at AC-3 	100 A
— at 400 V rated value	185 A
— at 500 V rated value	185 A
— at 690 V rated value	170 A
— at 1000 V rated value	65 A
• at AC-3e	
— at 400 V rated value	185 A
— at 500 V rated value	185 A
— at 690 V rated value	170 A
— at 1000 V rated value	65 A
• at AC-4 at 400 V rated value	160 A
• at AC-5a up to 690 V rated value	189 A
• at AC-5b up to 400 V rated value	153 A
• at AC-6a	
— up to 230 V for current peak value n=20 rated value	157 A
— up to 400 V for current peak value n=20 rated value	157 A
— up to 500 V for current peak value n=20 rated value	157 A
— up to 690 V for current peak value n=20 rated value	157 A
 up to 1000 V for current peak value n=20 rated value 	65 A
• at AC-6a	
— up to 230 V for current peak value n=30 rated value	105 A
— up to 400 V for current peak value n=30 rated value	105 A
— up to 500 V for current peak value n=30 rated value	105 A
— up to 690 V for current peak value n=30 rated value	105 A
— up to 1000 V for current peak value n=30 rated value	65 A
minimum cross-section in main circuit at maximum AC-1 rated value	95 mm²
operational current for approx. 200000 operating cycles at AC-4	
• at 400 V rated value	81 A
at 690 V rated value	65 A
operational current	
at 1 current path at DC-1	
— at 24 V rated value	160 A
— at 60 V rated value	160 A
— at 110 V rated value	18 A
— at 220 V rated value	3.4 A
— at 440 V rated value	0.8 A
— at 600 V rated value	0.5 A

	with 2 current paths in series at DC-1	
	-	160 A
with 3 current paths in series at DC-1 -at 24 V raded value		
		1.0 A
	-	160 A
at 500 V rated value - at 1 current path at DC-3 at DC-5 at 24 V rated value - at 600 V rated value - at 24 V rated value - at 600 V rated value - at 500 V rated value - at 600 V rated value - at 100 V rated value - at 100 V rated value - at 100 V rated value - at 440 V rated value - at 600 V rated		
• at 1 current path at DC-3 at DC-5 — at 624 V rated value — at 600 V rated value — at 400 V rated value — at 600 V rated value — at 600 V rated value — at 600 V rated value — at 500 V rated value — at 600 V rated value — at 24 V rated value — at 25 A — at 24 V rated value — at 20 V rated value — 300 V		
at 60 V rated value	•	160 Δ
at 220 V rated value		
at 440 V rated value at 600 V rated value at 110 V rated value at 250 V rated value 25.5 A 25.		
with 2 current paths in series at DC-3 at DC-5		
	-	160 A
■ with 3 current paths in series at DC-3 at DC-5 ■ at 24 V rated value ■ at 60 V rated value ■ at 60 V rated value ■ at 100 V rated value ■ at 440 V rated value ■ at 590 V rated value ■ at 1000 V rated value ■ at 590 V rated value ■ at 1000 V rated value ■ at 590 V rated value ■ at 1000 V rated value ■ at		
at 24 V rated value 160 A at 60 V rated value 160 A at 110 V rated value 160 A at 110 V rated value 160 A at 220 V rated value 160 A at 220 V rated value 150 A at 220 V rated value 17.4 A at 600 V rated value 0.75 A at 230 V rated value 0.75 A at 230 V rated value 90 kW at 1500 V rated value 90 kW at 230 V rated value 90 kW at 2400 V rated value 90 kW at 250 V rated value 90 kW at 250 V rated value 90 kW at 250 V rated value 90 kW at 1500 V rated value 90 kW at 1500 V rated value 90 kW at 690 V rated value 150 kW at 690 V rated value 150 kW at 1500 V rocurrent peak value n=20 rated value 150 kW at 1500 V for current peak value n=20 rated value 150 kVA at 150	— at 600 V rated value	
at 24 V rated value 160 A at 60 V rated value 160 A at 110 V rated value 160 A at 110 V rated value 160 A at 220 V rated value 160 A at 220 V rated value 150 A at 220 V rated value 17.4 A at 600 V rated value 0.75 A at 230 V rated value 0.75 A at 230 V rated value 90 kW at 1500 V rated value 90 kW at 230 V rated value 90 kW at 2400 V rated value 90 kW at 250 V rated value 90 kW at 250 V rated value 90 kW at 250 V rated value 90 kW at 1500 V rated value 90 kW at 1500 V rated value 90 kW at 690 V rated value 150 kW at 690 V rated value 150 kW at 1500 V rocurrent peak value n=20 rated value 150 kW at 1500 V for current peak value n=20 rated value 150 kVA at 150	 with 3 current paths in series at DC-3 at DC-5 	
- at 110 V rated value 160 A 1	-	160 A
- at 220 V rated value	— at 60 V rated value	160 A
at 440 V rated value	— at 110 V rated value	160 A
operating power	— at 220 V rated value	160 A
• at AC-3 — at 230 V rated value — at 400 V rated value — at 500 V rated value — at 690 V rated value — at 1000 V rated value — at 1000 V rated value — at 1000 V rated value — at 230 V rated value — at 400 V rated value — at 400 V rated value — at 500 V rated value — at 690 V rated value — at 690 V rated value — at 1000 V rated value — at 90 kW operating power for approx. 200000 operating cycles at AC-4 4 at 400 V rated value — at 690 V rated value — 65 kW operating apparent power at AC-6a — up to 230 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 690 V for current peak value n=20 rated value — up to 690 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 500 V for current peak value n=20 rated value — up to 500 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value — up to 230 V for current peak value n=30 rated value	— at 440 V rated value	1.4 A
• at AC-3 — at 230 V rated value	— at 600 V rated value	0.75 A
- at 230 V rated value 55 kW - at 400 V rated value 90 kW - at 500 V rated value 132 kW - at 690 V rated value 160 kW - at 1000 V rated value 90 kW • at AC-3e - at 230 V rated value 55 kW - at 400 V rated value 90 kW - at 400 V rated value 90 kW - at 500 V rated value 90 kW - at 500 V rated value 90 kW - at 690 V rated value 132 kW - at 690 V rated value 90 kW - at 690 V rated value 90 kW - at 690 V rated value 65 kW - at 400 V rated value 65 kW operating power for approx. 200000 operating cycles at AC-4 • at 400 V rated value 65 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value 100 kVA • up to 500 V for current peak value n=20 rated value 130 kVA • up to 500 V for current peak value n=20 rated value 130 kVA • up to 500 V for current peak value n=20 rated value 130 kVA • up to 500 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 230 V for current peak value n=20 rated value 180 kVA • up to 230 V for current peak value n=30 rated value 140 kVA operating apparent power at AC-6a • up to 230 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA	operating power	
- at 400 V rated value 90 kW - at 500 V rated value 132 kW - at 690 V rated value 90 kW - at 1000 V rated value 90 kW • at AC-3e - at 230 V rated value 90 kW - at 400 V rated value 90 kW - at 500 V rated value 90 kW - at 500 V rated value 90 kW - at 500 V rated value 90 kW - at 690 V rated value 160 kW - at 1000 V rated value 90 kW Operating power for approx. 200000 operating cycles at AC-4 • at 400 V rated value 55 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value 100 kVA • up to 500 V for current peak value n=20 rated value 130 kVA • up to 690 V for current peak value n=20 rated value 130 kVA • up to 690 V for current peak value n=20 rated value 180 kVA • up to 500 V for current peak value n=20 rated value 180 kVA • up to 500 V for current peak value n=20 rated value 180 kVA • up to 500 V for current peak value n=20 rated value 180 kVA • up to 230 V for current peak value n=20 rated value 180 kVA • up to 230 V for current peak value n=20 rated value 140 kVA • up to 230 V for current peak value n=20 rated value 40 kVA • up to 230 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA	• at AC-3	
- at 500 V rated value	— at 230 V rated value	55 kW
- at 690 V rated value - at 1000 V rated value 90 kW • at AC-3e - at 230 V rated value 90 kW - at 400 V rated value 90 kW - at 500 V rated value 90 kW - at 500 V rated value 132 kW - at 690 V rated value 90 kW operating power for approx. 200000 operating cycles at AC-4 • at 400 V rated value 90 kW operating power for approx. 200000 operating cycles at AC-4 • at 400 V rated value 95 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value 90 kVA • up to 500 V for current peak value n=20 rated value 130 kVA • up to 690 V for current peak value n=20 rated value 130 kVA • up to 1000 V for current peak value n=20 rated value 130 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 40 kVA	— at 400 V rated value	90 kW
- at 1000 V rated value • at AC-3e - at 230 V rated value - at 400 V rated value - at 500 V rated value - at 690 V rated value - at 1000 V rated value - at 400 V rated value - at 690	— at 500 V rated value	132 kW
at AC-3e — at 230 V rated value — at 400 V rated value — at 500 V rated value — at 500 V rated value — at 690 V rated value — at 1000 V rated value — at 690 V rated value • at 400 V rated value • at 690 V rated value • at 690 V rated value • 65 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value • up to 690 V for current peak value n=20 rated value • up to 690 V for current peak value n=20 rated value • up to 1000 V for current peak value n=20 rated value • up to 230 V for current peak value n=30 rated value • up to 230 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value	— at 690 V rated value	160 kW
- at 230 V rated value 55 kW - at 400 V rated value 90 kW - at 690 V rated value 160 kW - at 1000 V rated value 90 kW Operating power for approx. 200000 operating cycles at AC-4 • at 400 V rated value 45 kW • at 690 V rated value 65 kW Operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value 100 kVA • up to 690 V for current peak value n=20 rated value 130 kVA • up to 690 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 230 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 230 V for current peak value n=30 rated value 110 kVA Operating apparent power at AC-6a • up to 230 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 70 kVA	— at 1000 V rated value	90 kW
- at 400 V rated value - at 500 V rated value - at 690 V rated value - at 1000 V rated value 90 kW operating power for approx. 200000 operating cycles at AC-4 • at 400 V rated value • at 690 V rated value • at 690 V rated value • at 690 V rated value • at 690 V rated value • 65 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value • up to 400 V for current peak value n=20 rated value • up to 500 V for current peak value n=20 rated value • up to 690 V for current peak value n=20 rated value • up to 1000 V for current peak value n=20 rated value • up to 230 V for current peak value n=20 rated value • up to 230 V for current peak value n=30 rated value • up to 230 V for current peak value n=30 rated value • up to 230 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • 0 kVA	• at AC-3e	
- at 500 V rated value - at 690 V rated value - at 1000 V rated value 90 kW operating power for approx. 200000 operating cycles at AC- 4 • at 400 V rated value • at 690 V rated value • at 690 V rated value • at 690 V rated value • 65 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value • up to 400 V for current peak value n=20 rated value • up to 500 V for current peak value n=20 rated value • up to 690 V for current peak value n=20 rated value • up to 1000 V for current peak value n=20 rated value • up to 230 V for current peak value n=20 rated value • up to 1000 V for current peak value n=20 rated value • up to 230 V for current peak value n=30 rated value • up to 230 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value • 70 kVA	— at 230 V rated value	55 kW
- at 690 V rated value - at 1000 V rated value 90 kW operating power for approx. 200000 operating cycles at AC- 4 • at 400 V rated value • at 690 V rated value • at 690 V rated value • 65 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value • up to 400 V for current peak value n=20 rated value • up to 500 V for current peak value n=20 rated value • up to 690 V for current peak value n=20 rated value 130 kVA • up to 1000 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 110 kVA operating apparent power at AC-6a • up to 230 V for current peak value n=30 rated value • up to 400 V for current peak value n=30 rated value 70 kVA	— at 400 V rated value	90 kW
operating power for approx. 200000 operating cycles at AC- at 400 V rated value at 690 V rated value 65 kW operating apparent power at AC-6a up to 230 V for current peak value n=20 rated value up to 400 V for current peak value n=20 rated value up to 500 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value 130 kVA up to 690 V for current peak value n=20 rated value 180 kVA up to 1000 V for current peak value n=20 rated value 110 kVA operating apparent power at AC-6a up to 230 V for current peak value n=30 rated value 40 kVA up to 400 V for current peak value n=30 rated value 70 kVA	— at 500 V rated value	132 kW
operating power for approx. 200000 operating cycles at AC- 4 • at 400 V rated value • at 690 V rated value 65 kW operating apparent power at AC-6a • up to 230 V for current peak value n=20 rated value • up to 400 V for current peak value n=20 rated value • up to 500 V for current peak value n=20 rated value 100 kVA • up to 500 V for current peak value n=20 rated value 130 kVA • up to 690 V for current peak value n=20 rated value 180 kVA • up to 1000 V for current peak value n=20 rated value 110 kVA operating apparent power at AC-6a • up to 230 V for current peak value n=30 rated value 40 kVA • up to 400 V for current peak value n=30 rated value 70 kVA	— at 690 V rated value	160 kW
at 400 V rated value at 690 V rated value be at 690 V rated value coperating apparent power at AC-6a up to 230 V for current peak value n=20 rated value up to 400 V for current peak value n=20 rated value up to 500 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value to 100 kVA up to 690 V for current peak value n=20 rated value to 180 kVA up to 1000 V for current peak value n=20 rated value to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value va		90 kW
operating apparent power at AC-6a up to 230 V for current peak value n=20 rated value up to 400 V for current peak value n=20 rated value up to 500 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value vup to 400 V for current peak value n=30 rated value vup to 400 V for current peak value n=30 rated value vup to 400 V for current peak value n=30 rated value		
operating apparent power at AC-6a oup to 230 V for current peak value n=20 rated value oup to 400 V for current peak value n=20 rated value oup to 500 V for current peak value n=20 rated value oup to 690 V for current peak value n=20 rated value oup to 1000 V for current peak value n=20 rated value 130 kVA oup to 1000 V for current peak value n=20 rated value 110 kVA operating apparent power at AC-6a oup to 230 V for current peak value n=30 rated value 40 kVA oup to 400 V for current peak value n=30 rated value 70 kVA	• at 400 V rated value	45 kW
 up to 230 V for current peak value n=20 rated value up to 400 V for current peak value n=20 rated value up to 500 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value value n=30 rated value 	at 690 V rated value	65 kW
 up to 400 V for current peak value n=20 rated value up to 500 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value to kVA up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value value n=30 rated value 	operating apparent power at AC-6a	
 up to 500 V for current peak value n=20 rated value up to 690 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value 180 kVA 110 kVA Operating apparent power at AC-6a up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value 70 kVA 	 up to 230 V for current peak value n=20 rated value 	60 kVA
 up to 690 V for current peak value n=20 rated value up to 1000 V for current peak value n=20 rated value 110 kVA Operating apparent power at AC-6a up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value value n=30 rated value 70 kVA	• up to 400 V for current peak value n=20 rated value	100 kVA
 up to 1000 V for current peak value n=20 rated value operating apparent power at AC-6a up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value 70 kVA 	• up to 500 V for current peak value n=20 rated value	130 kVA
 operating apparent power at AC-6a up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value 40 kVA 70 kVA 	• up to 690 V for current peak value n=20 rated value	180 kVA
 up to 230 V for current peak value n=30 rated value up to 400 V for current peak value n=30 rated value 40 kVA 70 kVA 		110 kVA
• up to 400 V for current peak value n=30 rated value 70 kVA	operating apparent power at AC-6a	
• up to 500 V for current peak value n=30 rated value 90 kVA		
	up to 500 V for current peak value n=30 rated value	90 kVA

• up to 690 V for current peak value n=30 rated value	120 kVA
• up to 1000 V for current peak value n=30 rated value	110 kVA
short-time with stand current in cold operating state up to 40 $^{\circ}\text{C}$	
• limited to 1 s switching at zero current maximum	2 900 A; Use minimum cross-section acc. to AC-1 rated value
Iimited to 5 s switching at zero current maximum	2 084 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 10 s switching at zero current maximum 	1 480 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 30 s switching at zero current maximum 	968 A; Use minimum cross-section acc. to AC-1 rated value
 limited to 60 s switching at zero current maximum 	801 A; Use minimum cross-section acc. to AC-1 rated value
no-load switching frequency	
• at AC	1 000 1/h
• at DC	1 000 1/h
operating frequency	
• at AC-1 maximum	800 1/h
at AC-2 maximum	300 1/h
at AC-3 maximum	750 1/h
• at AC-3e	700 1/11
— maximum	750 1/h
at AC-4 maximum	130 1/h
• at AC-4 maximum Control circuit/ Control	100 1/11
	ACIDO
type of voltage of the control supply voltage	AC/DC
control supply voltage at AC	000 077.1/
at 50 Hz rated value	200 277 V
at 60 Hz rated value	200 277 V
control supply voltage at DC rated value	200 277 V
operating range factor control supply voltage rated value of magnet coil at DC	
initial value	0.8
full-scale value	1.1
operating range factor control supply voltage rated value of magnet coil at AC	
● at 50 Hz	0.8 1.1
• at 60 Hz	0.8 1.1
type of PLC-control input according to IEC 60947-1	Type 2
consumed current at PLC-control input according to IEC 60947-1 maximum	20 mA
voltage at PLC-control input rated value	24 V
operating range factor of the voltage at PLC-control input	0.8 1.1
design of the surge suppressor	with varistor
apparent pick-up power	
 at minimum rated control supply voltage at AC 	
— at 50 Hz	190 VA
— at 60 Hz	190 VA
 at maximum rated control supply voltage at AC 	
— at 60 Hz	280 VA
— at 50 Hz	280 VA
apparent pick-up power of magnet coil at AC	
● at 50 Hz	280 VA
• at 60 Hz	280 VA
inductive power factor with closing power of the coil	
• at 50 Hz	0.8
• at 60 Hz	0.8
apparent holding power	
 at minimum rated control supply voltage at DC 	2.1 VA
at maximum rated control supply voltage at DC	2.8 VA
apparent holding power	
at minimum rated control supply voltage at AC	
— at 50 Hz	3.5 VA
— at 60 Hz	3.5 VA
at maximum rated control supply voltage at AC	
— at 50 Hz	4.8 VA
— at 60 Hz	4.8 VA
UL OU TIZ	no m

inductive power factor with the holding power of the coil	
● at 50 Hz	0.6
● at 60 Hz	0.6
closing power of magnet coil at DC	320 W
holding power of magnet coil at DC	2.8 W
closing delay	
• at AC	35 75 ms
• at DC	35 75 ms
opening delay	00 70 HIS
• at AC	80 90 ms
• at DC	80 90 ms
arcing time	10 15 ms
control version of the switch operating mechanism	PLC-IN or Standard A1 - A2 (adjustable)
Auxiliary circuit	1 LO-IN OF Standard AT - AZ (adjustable)
number of NC contacts for auxiliary contacts instantaneous contact	2
number of NO contacts for auxiliary contacts instantaneous contact	2
operational current at AC-12 maximum	10 A
operational current at AC-15	
at 230 V rated value	6 A
at 400 V rated value	3 A
at 400 V rated value at 500 V rated value	2 A
	1 A
at 690 V rated value	10
operational current at DC-12	10.4
• at 24 V rated value	10 A
• at 48 V rated value	6 A
at 60 V rated value	6 A
at 110 V rated value	3 A
• at 125 V rated value	2 A
• at 220 V rated value	1 A
at 600 V rated value	0.15 A
operational current at DC-13	
• at 24 V rated value	10 A
at 48 V rated value	2 A
 at 60 V rated value 	2 A
at 110 V rated value	1 A
at 125 V rated value	0.9 A
at 220 V rated value	0.3 A
at 600 V rated value	0.1 A
contact reliability of auxiliary contacts	1 faulty switching per 100 million (17 V, 1 mA)
UL/CSA ratings	
full-load current (FLA) for 3-phase AC motor	
• at 480 V rated value	180 A
at 600 V rated value	192 A
yielded mechanical performance [hp]	
 for single-phase AC motor 	
— at 230 V rated value	30 hp
• for 3-phase AC motor	
— at 200/208 V rated value	60 hp
— at 220/230 V rated value	75 hp
— at 460/480 V rated value	150 hp
— at 575/600 V rated value	200 hp
contact rating of auxiliary contacts according to UL	A600 / Q600
Short-circuit protection	
design of the miniature circuit breaker for short-circuit protection of the auxiliary circuit up to 230 V	C characteristic: 10 A; 0.4 kA
design of the fuse link	
• for short-circuit protection of the main circuit	
 — with type of coordination 1 required 	gG: 355 A (690 V, 100 kA)
 — with type of coordination 2 required 	gG: 315 A (690 V, 100 kA), aM: 200 A (690 V, 50 kA), BS88: 315 A (415 V, 50

for short-circuit protection of the auxiliary switch required	gG: 10 A (500 V, 1 kA)
Installation/ mounting/ dimensions	35. 10.1.(000 1, 1.10)
mounting position	with vertical mounting surface +/-90° rotatable, with vertical mounting surface +/- 22.5° tiltable to the front and back
fastening method side-by-side mounting	Yes
fastening method	screw fixing
height	172 mm
width	120 mm
depth	170 mm
required spacing	
with side-by-side mounting	
— forwards	20 mm
— upwards	10 mm
— downwards	10 mm
— at the side	0 mm
• for grounded parts	
— forwards	20 mm
— upwards	10 mm
— at the side	10 mm
— downwards	10 mm
• for live parts	20 mm
— forwards	20 mm
— upwards — downwards	10 mm 10 mm
— downwards — at the side	10 mm
— at the side Connections/ Terminals	IV IIIII
type of electrical connection • for main current circuit	Connection bar
for main current circuit for auxiliary and control circuit	screw-type terminals
at contactor for auxiliary contacts	Screw-type terminals Screw-type terminals
of magnet coil	Screw-type terminals Screw-type terminals
width of connection bar	17 mm
thickness of connection bar	3 mm
diameter of holes	9 mm
number of holes	1
type of connectable conductor cross-sections	
for AWG cables for main contacts	4 250 kcmil
connectable conductor cross-section for main contacts	
• stranded	25 120 mm²
connectable conductor cross-section for auxiliary contacts	
solid or stranded	0.5 4 mm²
finely stranded with core end processing	0.5 2.5 mm²
type of connectable conductor cross-sections	
• for auxiliary contacts	
— solid	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²), max. 2x (0.75 4 mm²)
— solid or stranded	2x (0,5 1,5 mm²), 2x (0,75 2,5 mm²), max. 2x (0,75 4 mm²)
 finely stranded with core end processing 	2x (0.5 1.5 mm²), 2x (0.75 2.5 mm²)
for AWG cables for auxiliary contacts	2x (20 16), 2x (18 14), 1x 12
AWG number as coded connectable conductor cross section for auxiliary contacts	18 14
Safety related data	
product function	
 mirror contact according to IEC 60947-4-1 	Yes
 positively driven operation according to IEC 60947-5-1 	No
suitable for safety function	Yes
suitability for use safety-related switching OFF	Yes; safety-related disconnection via A1 A2
service life maximum	20 a
test wear-related service life necessary	Yes
proportion of dangerous failures	
with low demand rate according to SN 31920	40 %
with high demand rate according to SN 31920	73 %

B10 value with high demand rate according to SN 31920	1 000 000
failure rate [FIT] with low demand rate according to SN 31920	100 FIT
ISO 13849	
device type according to ISO 13849-1	3
overdimensioning according to ISO 13849-2 necessary	Yes
IEC 61508	
safety device type according to IEC 61508-2	Type A
Electrical Safety	
protection class IP on the front according to IEC 60529	IP00; IP20 with box terminal/cover
touch protection on the front according to IEC 60529	finger-safe, for vertical contact from the front with box terminal/cover
Approvals Certificates	

General Product Approval









<u>KC</u>



EMV Functional Saftey Test Certificates Maritime application



Type Examination Certificate

Type Test Certificates/Test Report

Special Test Certificate





Maritime application other









Confirmation

Miscellaneous

other Railway Environment

<u>Confirmation</u> <u>Miscellaneous</u> <u>Special Test Certification Environmental Conate firmations</u>

Further information

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information for data generation and storage

https://support.industry.siemens.com/cs/ww/en/view/109995012

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3RT1056-6NP36

Cax online generator

http://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en&mlfb=3RT1056-6NP36

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3RT1056-6NP36

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)


http://www.automation.siemens.com/bilddb/cax_de.aspx?mlfb=3RT1056-6NP36&lang=en


Characteristic: Tripping characteristics, I^2t , Let-through current


https://support.industry.siemens.com/cs/ww/en/ps/3RT1056-6NP36/char


Further characteristics (e.g. electrical endurance, switching frequency)

http://www.automation.siemens.com/bilddb/index.aspx?view=Search&mlfb=3RT1056-6NP36&objecttype=14&gridview=view1









last modified:

4/17/2025

