## **SIEMENS**

Data sheet 3UG4631-2AA30



!!! product phase-out !!! the preferred successor is 3UG5642-2CW30 digital monitoring relay voltage monitoring, 22.5 mm from 0.1 to 60 V AC/DC overshoot and undershoot supply voltage: 24 V AC/DC 50 to 60 Hz DC and AC without electrical isolation to measuring circuit noise pulses delay 0.1 to 20 s hysteresis 0.1 to 30 V 1 changeover contact with or without fault buffer spring-loaded connection system

| product brand name   | SIRIUS  |
|--|---|
| product designation  | Voltage monitoring relay with digital setting   |
| product type designation   | 3UG4  |
| eneral technical data  |   |
| product function   | Voltage monitoring relay  |
| design of the display  | LCD   |
| insulation voltage for overvoltage category III according to IEC 60664 |   |
| <ul> <li>with degree of pollution 3 rated value</li> </ul>             | 690 V   |
| type of voltage  |   |
| <ul> <li>for monitoring</li> </ul>                                     | AC/DC   |
| <ul> <li>of the control supply voltage</li> </ul>                      | AC/DC   |
| surge voltage resistance rated value                                   | 4 kV  |
| maximum permissible voltage for protective separation                  |   |
| <ul> <li>between auxiliary and auxiliary circuit</li> </ul>            | 300 V   |
| <ul> <li>between control and auxiliary circuit</li> </ul>              | 300 V   |
| shock resistance according to IEC 60068-2-27                           | sinusoidal half-wave 15g / 11 ms  |
| vibration resistance according to IEC 60068-2-6                        | 1 6 Hz: 15 mm, 6 500 Hz: 2g   |
| mechanical service life (operating cycles) typical                     | 10 000 000  |
| electrical endurance (operating cycles) at AC-15 at 230 V typical      | 100 000   |
| thermal current of the switching element with contacts maximum         | 5 A   |
| reference code according to IEC 81346-2                                | К   |
| relative repeat accuracy   | 1 %   |
| Substance Prohibitance (Date)  | 05/01/2012  |
| SVHC substance name  | Lead - 7439-92-1<br>Lead monoxide (lead oxide) - 1317-36-8<br>6,6'-di-tert-butyl-2,2'-methylenedi-p-cresol - 119-47-1 |
| Net Weight   | 0.129 kg  |
| roduct Function  |   |
| product function   |   |
| undervoltage detection   | Yes   |
| overvoltage detection  | Yes   |
| <ul> <li>overvoltage detection 1 phase</li> </ul>                      | Yes   |
| <ul> <li>overvoltage detection 3 phase</li> </ul>                      | No  |
| overvoltage detection DC   | Yes   |
| undervoltage detection 1 phase   | Yes   |
| • undervoltage detection 3 phases                                      | No  |
| undervoltage detection DC  | Yes   |
| <ul> <li>voltage window recognition 1 phase</li> </ul>                 | Yes   |

| <ul> <li>voltage window recognition 3 phase</li> </ul>                      | No         |
|---|------------|
| <ul> <li>voltage window recognition DC</li> </ul>                           | Yes        |
| <ul> <li>adjustable open/closed-circuit current principle</li> </ul>        | Yes        |
| external reset  | Yes        |
| • auto-RESET  | Yes        |
| Control circuit/ Control  |            |
| control supply voltage at AC  |            |
| at 50 Hz rated value  | 24 V       |
| at 50 Hz rated value  | 24 240 V   |
| at 60 Hz rated value  | 24 V       |
| at 60 Hz rated value  | 24 240 V   |
| control supply voltage at DC rated value                                    | 24 V       |
| control supply voltage at DC rated value                                    | 24 240 V   |
| operating range factor control supply voltage rated value at<br>DC          |            |
| ● initial value   | 0.85       |
| full-scale value  | 1.15       |
| operating range factor control supply voltage rated value at AC at 50 Hz    |            |
| • initial value   | 0.85       |
| • full-scale value  | 1.15       |
| operating range factor control supply voltage rated value at AC at 60 Hz    |            |
| • initial value   | 0.85       |
| • full-scale value  | 1.15       |
| Measuring circuit   |            |
| measurable line frequency   | 40 500 Hz  |
| measurable voltage at AC  | 0 60 V     |
| measurable voltage at DC  | 0.1 60 V   |
| adjustable response delay time  |            |
| <ul><li>when starting</li></ul>   | 20 s       |
| <ul> <li>with lower or upper limit violation</li> </ul>                     | 0.1 20 s   |
| accuracy of digital display   | +/-1 digit |
| relative temperature-related measurement deviation                          | 0.1 %      |
| Precision   |            |
| relative metering precision   | 5 %        |
| Auxiliary circuit   |            |
| number of NC contacts delayed switching                                     | 0          |
| number of NO contacts delayed switching                                     | 0          |
| number of CO contacts delayed switching                                     | 1          |
| operating frequency with 3RT2 contactor maximum                             | 5 000 1/h  |
| Main circuit  |            |
| number of poles for main current circuit                                    | 1          |
| operating voltage   |            |
| • at AC   |            |
| — at 50 Hz rated value  | 240 240 V  |
| — at 60 Hz rated value  | 240 240 V  |
| at DC rated value   | 24 24 V    |
| ampacity of the output relay at AC-15 at 400 V at 50/60 Hz                  | 3 A        |
| ampacity of the output relay at DC-13                                       |            |
| • at 24 V   | 1 A        |
| • at 125 V  | 0.2 A      |
| ● at 250 V  | 0.1 A      |
| operational current at 17 V minimum   | 5 mA       |
| continuous current of the DIAZED fuse link of the output relay              | 4 A        |
| Electromagnetic compatibility   |            |
| conducted interference  |            |
| <ul> <li>due to burst according to IEC 61000-4-4</li> </ul>                 | 2 kV       |
|   |            |
| <ul> <li>due to conductor-earth surge according to IEC 61000-4-5</li> </ul> | 2 kV       |

| <ul> <li>due to conductor-conductor surge according to IEC<br/>61000-4-5</li> </ul>   | 1 kV   |
|---|--|
| field-based interference according to IEC 61000-4-3   | 10 V/m   |
| electrostatic discharge according to IEC 61000-4-2  | 6 kV contact discharge / 8 kV air discharge                              |
| Galvanic isolation  | O NV CONTROCT CHOCKING GOVERNMENT  |
| design of the electrical isolation  | Protective separation  |
| galvanic isolation  | 1 Totochive Separation   |
| between input and output  | Yes  |
| between the outputs   | Yes  |
| between the outputs     between the voltage supply and other circuits   | No   |
| Electrical Safety   | INO  |
| protection class IP on the front according to IEC 60529   | IP20   |
| Connections/ Terminals  | 11 20  |
| product component removable terminal for auxiliary and  | Yes  |
| control circuit   | 165  |
| type of electrical connection   | spring-loaded terminals  |
| type of connectable conductor cross-sections  |  |
| • solid   | 2x (0.25 1.5 mm²)  |
| <ul> <li>finely stranded with core end processing</li> </ul>  | 2 x (0.25 1.5 mm²)   |
| finely stranded without core end processing   | 2x (0.25 1.5 mm²)  |
| • for AWG cables solid  | 2x (24 16)   |
| • for AWG cables stranded   | 2x (24 16)   |
| connectable conductor cross-section   |  |
| • solid   | 0.25 1.5 mm²   |
| <ul> <li>finely stranded with core end processing</li> </ul>  | 0.25 1.5 mm²   |
| <ul> <li>finely stranded without core end processing</li> </ul>   | 0.25 1.5 mm²   |
| AWG number as coded connectable conductor cross section   |  |
| • solid   | 24 16  |
| • stranded  | 24 16  |
| Installation/ mounting/ dimensions  |  |
| installation/ mounting/ dimensions  |  |
| mounting position   | any  |
|   | any snap-on mounting   |
| mounting position   | ·  |
| mounting position fastening method height width   | snap-on mounting   |
| mounting position fastening method height width depth   | snap-on mounting<br>94 mm  |
| mounting position fastening method height width depth required spacing  | snap-on mounting 94 mm 22.5 mm   |
| mounting position fastening method height width depth required spacing • with side-by-side mounting   | snap-on mounting 94 mm 22.5 mm 91 mm                                     |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards   | snap-on mounting 94 mm 22.5 mm 91 mm                                     |
| mounting position fastening method height width depth required spacing • with side-by-side mounting   | snap-on mounting 94 mm 22.5 mm 91 mm 0 mm                                |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards   | snap-on mounting 94 mm 22.5 mm 91 mm 0 mm 0 mm                           |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm                |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side   | snap-on mounting 94 mm 22.5 mm 91 mm 0 mm 0 mm                           |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm      |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — forwards — backwards — backwards  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting  — forwards  — backwards  — upwards  — downwards  — at the side  • for grounded parts  — forwards  — backwards  — upwards  — upwards   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — backwards — upwards — at the side   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — at the side • to grounded parts — forwards — backwards — upwards — at the side — downwards  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — backwards — backwards — upwards — at the side — downwards • for live parts  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — backwards — upwards — obackwards — upwards — at the side — downwards • for live parts — forwards   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — backwards — torwards — backwards — upwards — at the side — downwards — at the side — downwards • for live parts — forwards — backwards — backwards  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — backwards — upwards   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — backwards — upwards — torwards — backwards — backwards — backwards — at the side  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — backwards — backwards — upwards — at the side • for live parts — forwards — backwards — at the side — downwards • for live parts — forwards — backwards — upwards — at the side — downwards — backwards — upwards — backwards — upwards — at the side  Ambient conditions   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side  • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — at the side Ambient conditions installation altitude at height above sea level maximum   | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  • with side-by-side mounting — forwards — backwards — upwards — downwards — at the side • for grounded parts — forwards — backwards — upwards — at the side • for grounded parts — forwards — backwards — upwards — at the side — downwards • for live parts — forwards — backwards — upwards — backwards — upwards — at the side Ambient conditions installation altitude at height above sea level maximum ambient temperature • during operation | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |
| mounting position fastening method height width depth required spacing  | snap-on mounting 94 mm 22.5 mm 91 mm  0 mm 0 mm 0 mm 0 mm 0 mm 0 mm 0 mm |

| Environmental footprint                                |          |
|--|----------|
| Environmental Product Declaration(EPD)                 | Yes      |
| global warming potential [CO2 eq] total                | 17.1 kg  |
| global warming potential [CO2 eq] during manufacturing | 4.44 kg  |
| global warming potential [CO2 eq] during operation     | 13.7 kg  |
| global warming potential [CO2 eq] after end of life    | -1.06 kg |
| Approvals Certificates                                 |          |



**General Product Approval** 











**EMV** 

EMV Test Certificates Maritime application other

KC Type Test Certificates/Test Report

Special Test Certificate





Confirmation

other Railway Environment



Special Test Certificate



Environmental Confirmations

## Further information

Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information for data generation and storage

https://support.industry.siemens.com/cs/ww/en/view/109995012

Information- and Downloadcenter (Catalogs, Brochures,...)

https://www.siemens.com/ic10

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=3UG4631-2AA30

Cax online generator


 $\underline{https://support.automation.siemens.com/WW/CAXorder/default.aspx?lang=en\&mlfb=3UG4631-2AA30}$ 


Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/3UG4631-2AA30

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, EPLAN macros, ...)

 $\underline{https://www.automation.siemens.com/bilddb/cax\_de.aspx?mlfb=3UG4631-2AA30\&lang=endersen$ 





last modified: 10/17/2025 🖸